



12

## EC - DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.  
P.O. Box 373  
Michigan City, IN 46361, USA  
(219) 879-8868

declare under our sole responsibility that our Series CDT and CDTR Duct Mount Carbon Dioxide/Temperature/Relative Humidity Transmitters to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

EN 61326-1 (2006) Electrical Equipment for Measurement, Control, and Laboratory Use - EMC Requirements -Part 1: General Requirements

IEC 61000-4-2 (2008) Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3 (2010) Electromagnetic Compatibility (EMC) - Part 4-3 Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4 (2010) Part 4-4 Testing and Measurement Techniques – Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-6: (2008) Part 4-6 Testing and Measurement Techniques – Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields

EN 55011 (2010) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment – Electromagnetic Disturbance Characteristics – Limits and Methods of Measurement Class B

The authorized representative located within the Community is:

Dwyer Instruments Ltd  
Unit 16, The Wye Estate, London Road  
High Wycombe, Bucks HP11 1LH-U.K.  
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Senior Regulatory Engineer

Michigan City, Indiana, USA  
10/9/12