



# 10

## EC - DECLARATION OF CONFORMITY

We, **Dwyer Instruments, Inc.**  
P.O. Box 373  
Michigan City, IN 46361, USA  
(219) 879-8868

declare under our sole responsibility that our Series TDFS Thermal Dispersion Flow Switch to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 104/108/EC (EMC)

CENELEC EN 55011: 2006 Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment – Electromagnetic Disturbance Characteristics – limits and Methods of Measurement

CENELEC EN 613326-1: 2006 Electrical Equipment for Measurement, Control and Laboratory Use – EMC Requirements Part - General Requirements

IEC 61000-4-2: 2008 Part 4-2 Test and Measurement Techniques – Electrostatic Discharge Immunity Test

IEC 61000-4-3: 2006 Part 4-3 Testing and Measurement Techniques – Radiated, Radio-Frequency, Electromagnetic Field Immunity Test (Test Level: 10 V/m; 80-1000 MHz and 3 V/m; 1400-2700 MHz)

IEC 61000-4-4: 2004 Part 4-4 Testing and Measurement Techniques – Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-5: 2005 Part 4-4 Testing and Measurement Techniques – Surge Immunity Test

IEC 61000-4-6: 2006 Part 4-6 Testing and Measurement Techniques – Immunity to Conducted Disturbances, Induced by Radio-Frequency Fields

CENELEC EN 55022: 2006 Information Technology Equipment – Radio Disturbance Characteristics – Limits

The authorized representative located within the Community is:

Dwyer Instruments Ltd  
Unit 16, The Wye Estate, London Road  
High Wycombe, Bucks HP11 1LH-U.K.  
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Senior Regulatory Engineer

Michigan City, Indiana, USA

3/31/10