PULSAR MEASUREMENT









Instruction Manual

Note: This page has been left blank intentionally.

CONTENTS

EU DECLARATION OF CONFORMITY	4
CONNECTIONS	5
HAZARDOUS AREA WIRING INSTRUCTIONS	7
KEYPAD SYSTEM	8
CALIBRATION MENU	9
ICONS	10
MAIN DISPLAY	11
MESSAGE ICON	11
STATUS	11
PASSWORD	12
MENU SELECTIONS	12
UNITS/MODE	13
CALIBRATION	15
RELAY PARAMETERS	17
DATA LOGGING	18
COMMUNICATION (Optional)	20
SPECIAL FUNCTIONS	22
SENSOR MOUNTING LOCATION	25
ENCLOSURE INSTALLATION	29
FIELD TROUBLESHOOTING	30
COMMON QUESTIONS AND ANSWERS	33
APPLICATIONS HOTLINE	35
PRODUCT RETURN PROCEDURE	35
OPTIONS	37
MODBUS® COMMUNICATION	41
HART® COMMUNICATION	52
APPENDIX A – Classified Area Installation Control Drawings	64
APPENDIX B – Specifications	67
APPENDIX D – Pipe Charts	69

IMPORTANT NOTE: This instrument is manufactured and calibrated to meet product specifications. Please read this manual carefully before installation and operation. Any unauthorized repairs or modifications may result in a suspension of the warranty.

If this product is not used as specified by the manufacturer, protection may be impaired.

Available in Adobe Acrobat pdf format

EU DECLARATION OF CONFORMITY

EU Declaration of Conformity – Pulsar Measurement DFM 6.1 Transit-Time Flow Meter

This declaration of conformity is issues under the sole responsibility of the manufacturer.

Relevant Directive(s)	2014/30/EU – EMC directive and its amending directives 2014/35/EU – Low Voltage directive and its amending directives 2014/34/EU – ATEX directive and its amending directives 2011/65/EU – RoHS directive and its amending directives
Manufacturer's name	Pulsar Measurement
Manufacturer's address	16456 Sixsmith Drive
	Long Sault,
	ON KOC 1P0
	Canada
Apparatus	Doppler flow meter including wall-mount electronics, transducer cables, and transducer
Models	DFM 6.1 with SE4-A transducers (ATEX where approved)
Type of equipment	Measurement and process control
Standards applied	EN 61326-1:2013 EMC, equipment class industrial
	EN 61010-1:2010+A1:2019 Safety requirements for electrical equipment for measurement, control, and laboratory use
	EN IEC 60079-0:2018 ATEX general requirements
	EN 60079-11:2021 ATEX intrinsic safety (Ex ia)
Notified body	CSA Group Netherlands B.V. #2813
Role	Certifier of ATEX type examination CSANe 22ATEX1057X

I declare that the apparatus named above has been tested and complies with the relevant sections of the above referenced standards & directives.

Signed:

5/ 12/

Date: November 16, 2022 Rev. 1.0

Name & function

Ken Elander, Sr Product Manager

Pulsar Measurement

CONNECTIONS

POWER INPUT: The standard model requires AC power input between 100 to 240 VAC 50/60Hz. No adjustments are necessary for voltages within this range. Connect L (Live) N (Neutral) and AC Ground.

Optional DC input model requires 9-32 VDC/10 Watts. Connect to + and - terminals.

Optional Thermostat and Heater modules are available rated for 115 VAC or 230 VAC.

IMPORTANT NOTE: To comply with CSA/UL electrical safety standards, AC power input and relay connection wires must have conduit entry to the instrument enclosure. Installation requires a switch, overcurrent fuse or circuit breaker in the building (in close proximity to the equipment) that is marked as the disconnect switch.



Risk of electric shock. Loosen cover screw to access connections. Only qualified personnel should access connections.

Note: Use of instrumentation over 40°C ambient requires special field wiring.

QUICK BENCH TEST

Connect Sensor as shown on next page, then Power. Test operation of the DFM 6.1 by holding the sensor in one hand and rubbing your thumb or fingers briskly across the face (plastic surface) of the sensor. Allow 15 seconds for the DFM 6.1 to process the signal and display a flow value.

CONNECTIONS



HAZARDOUS AREA WIRING INSTRUCTIONS

The SE4-A transducer comes certified for use in the following hazardous locations. Please visit our website for copies of the approval letters from the certifying agencies.

Individual copies of the specific control drawings for proper installation are also available for download on the website, included with the shipment of each meter as a stand-alone document, and located within this manual in Appendix A.

Standard:

• CSA C/US Non-Incendive for Class I, Div 2, Groups A, B, C, D

Optional with Intrinsic Safety Barriers:

- CSA C/US Intrinsically safe for Class I, Div 1, Groups C,D; Class II, Div 1, Groups E,F,G; Class III; Encl. Type 4 or
- ATEX/IECEx Zone 0, Ex ia IIB T4 Ga

When using optional intrinsic safety barriers, follow the instructions in the control drawing for proper adherence to the conditions of acceptability. When the intrinsic safety barrier option is purchased with the DFM 6.1, the proper barriers come pre-installed inside the DFM 6.1 electronics housing.

KEYPAD SYSTEM

The diagram on the next page shows the DFM 6.1 menu system. Arrows show the four directions to leave a menu box. Pressing a corresponding keypad arrow will move to the next item in the direction shown. Move the cursor (highlighted) under numerals and increase or decrease numerals with the \blacktriangle and \blacktriangledown keys.

To store calibration values permanently (even through power interruptions), press the ✓ button.



CALIBRATION MENU



ICONS



PULSAR MEASUREMENT

à		USG/m
	(0.00
Tot Rel ays	1	20130 USG 2 3 4 5 6
Message DataLog LogUsed Sensor	s-	Logging 0.00000% Good

MAIN DISPLAY

The main display shows the units selected from the Units/Mode menu, flow or velocity rate being measured, totalizer and relay states. The DFM 6.1 will start-up with this display.

MESSAGE ICON

Press \blacktriangle from the main display to view status of the data logger and error/warning messages provided by the instrument. The Message lcon will appear on the main display if error messages are being generated by the instrument. Press \checkmark to return to the main display.

Sensor

Displays the status of the sensor hardware. Even with the sensor disconnected or shorted, the DFM will display Good. To check sensor integrity, use the sensor resistance test procedure on page 28. If HardwareFault is detected, navigate to the Configuration page in the Main Menu to determine which circuit board is not communicating.

Status	
▶Velocity	0.00ft/s
Flow	0.00 USG/ m
MinFlow	0.00USG/m
Si gnal	0 %
Signal Cut	off 10%

STATUS

Press \blacksquare from the main display to view instrument status. Velocity will be displayed in ft/sec or m/sec.

Velocity	Displays the measured flow velocity in units selected in the Units/Mode menu.
Flow	Displays the measured flow rate in units selected in the Units/Mode menu.
Min Flow	Displays the minimum flow rate setting. This value is read- only. The Min Flow can be changed in the Calibration programming menu. A measured Flow value below the Min Flow value will display as 0 flow on the meter's LCD display.
Signal	Displays the strength of the received Doppler signal on a 0-100% scale.
Signal Cutoff	Displays the signal cutoff. This value is read-only. The Signal Cutoff can be changed in the Calibration programming menu. If Signal Strength is less than Signal Cutoff, the meter will report 0 velocity and flow on the LCD display. Setting may need to be adjusted in the case of unstable flow near zero, or when high levels of industrial noise are

present.

24 hr 1	og
▶Date	Feb. 12/2010
Total	50138 USG
Average	34.82 USG/m
Maximum	52.20 USG/m
Max Time	11:08:00
Minimum	0.000 USG/m
Min Time	9:15:00

-Password-

Password

24 HR LOG

Press \blacktriangleleft from the main display to view a formatted flow report from instruments with a built-in data logger. Press \checkmark to scroll down one day or repeatedly to scroll to a specific date. Up to 365 days can be stored. Newest date will overwrite the oldest. Press \checkmark to return to the main display.

IMPORTANT: Inserting a USB drive into the meter while on this screen will transfer 24 HR Log data to the USB drive in .csv format.

PA	SSI	W	DR	D

0000

The Password (a number from 0000 to 9999) prevents unauthorized access to the Calibration menu.

From the Main Display press the \blacktriangleright key to get to Password. Factory default password is 0000 and if it has not been changed, this screen will be bypassed completely.

A new password can be stored by going to the Special Functions New Password menu.

If a user password is required, press \blacktriangleright to place the cursor under the first digit and \triangledown or \blacktriangle to set the number, then \blacktriangleright to the second digit, etc. Press \blacktriangleright or \checkmark to proceed to the Menu Selections screen.

MENU SELECTIONS

The Menu selections page is used to navigate to specific menus which are described in more detail on the following pages.

Press \blacktriangle or \triangledown to navigate to different menus, and \triangleright to enter the selected menu.

- Menu-----▶Units / Mode Calibration Relay Parameters Data Logging Communication Special Functions Simulation Configuration

Units/Mode	
▶ Mode	Flow
Linear	in
Volume	USG
Multiplier	x 1
Decimals	0
Velocity	ft/s
Flow	USG/m
Decimals	2

UNITS/MODE

At Mode, press the \blacktriangleright and then the \blacktriangle or \triangledown to select Flow or Velocity. Flow mode displays the flow rate in engineering units (e.g. gpm, litres/sec, etc.) Press the \checkmark to store your selection then the \triangledown to the next menu item.

At Linear press the \blacktriangleright key and then the \blacktriangle or \triangledown to select your units of measurement. The Linear units define what units the pipe dimensions and sensor spacing will be displayed in. Typically inches or mm is selected. Press the \checkmark to store your selection then the \checkmark to the next menu item.

At Volume, press the \blacktriangleright and then the \blacktriangle or \triangledown to select units for volume. Note: "bbl" denotes US oil barrels. Press the \checkmark to store your selection then the \triangledown to the next menu item.

At Multiplier, press the \blacktriangleright and then the \blacktriangle or \triangledown to select the totalizer multiplier. Multipliers are used when resolution down to single digit is not required, or when you don't want to convert from gallons to thousands of gallons, as an example. Press \checkmark to store your selection then \triangledown to the next menu item.

At Decimals (Volume), press the \blacktriangleright and then the \blacktriangle or \triangledown to select the number of decimal points to be present on the totalizer display on the LCD screen. Default = 0. Options = 0, 1, 2. Press the \checkmark to store your selection then the \blacktriangledown to the next menu item.

At Velocity, press the \blacktriangleright and then the \blacktriangle or \triangledown to select the engineering units for flow velocity. Press \checkmark to store your selection then \triangledown to the next menu item.

DFM 6.1 INSTRUCTION MANUAL

Units/Mode	
▶ Mode	Flow
Linear	in
Volume	USG
Multiplier	x 1
Decimals	0
Velocity	ft/s
Flow	USG/m
Decimals	2

UNITS/MODE (cont.)

At Flow, press the \blacktriangleright and then the \blacktriangle or \triangledown to select the engineering units for flow rate. Press \checkmark to store your selection then \triangledown to the next menu item.

Available Flow Rate Engineering Units:

Abbreviation	Description	Abbreviation	Description
USG/d	US gallons per day	L/d	liters per day
USG/h	US gallons per hour	L/h	liters per hour
USG/m	US gallons per minute	L/m	liters per minute
USG/s	US gallons per second	L/s	liters per second
ft³/d	cubic feet per day	m³/d	cubic meters per day
ft³/h	cubic feet per hour	m³/h	cubic meters per hour
ft³/m	cubic feet per minute	m³/m	cubic meters per minute
ft³/s	cubic feet per second	m³/s	cubic meters per second
bbl/d	barrels per day (1 bbl = 42 USG)	IG/d	Imperial gallons per day
bbl/h	barrels per hour (1 bbl = 42 USG)	IG/d	Imperial gallons per day
bbl/m	barrels per minute (1 bbl = 42 USG)	IG/d	Imperial gallons per day
bbl/d	barrels per second (1 bbl = 42 USG)	IG/d	Imperial gallons per day
USMG/d	US million gallons per day	IMG/d	Imperial million gallons per day
USMG/h	US million gallons per hour	IMG/h	Imperial million gallons per hour
USMG/m	US million gallons per minute	IMG/m	Imperial million gallons per minute
USMG/s	US million gallons per second	IMG/s	Imperial million gallons per second

At Decimals (Flow), press the \blacktriangleright and then the \blacktriangle or \blacktriangledown to select the number of decimal points to be present on the flow rate display on the LCD screen. Default = 2. Options = 0, 1, 2. Press the \checkmark to store your selection then the \blacktriangledown to the next menu item.

Calibration
▶ Mode Flow
20 mA 500 USG/m
4 mA 0 USG/ m
MinFlow 5.00USG/m
Signal Cutoff 10%
Damping
Mode FIR
Percent 10%
Window 1.0ft/s
PipeID 4.03 in
Cal Constant 1.000

CALIBRATION

Press \triangledown or \blacktriangle to position curser at Calibration menu, and \triangleright to enter. Use \triangledown or \blacktriangle to position cursor before each menu item and \triangleright to enter. When settings are completed press \checkmark to store and \checkmark again to return to the Main Menu.

20mA (5V)	Press \blacktriangleright then \blacktriangledown or \blacktriangle to change the numbers and decimal point. Use this menu to set the corresponding flow rate that will be represented by 20mA analog output. If maximum flow is unknown, enter an estimated flow rate and observe actual flow to determine the correct maximum value. Any velocity or flow rate up to +40 ft/sec (12.2 m/sec) may be selected.
4mA (0V)	Press \bigvee or \blacktriangle to set the flow rate corresponding to 4mA analog output. This setting may be left at zero flow (or velocity or can be raised to any value less than the 20mA setting, or lowered to any velocity or corresponding flow rate down to -40 ft/sec (-12.2 m/sec).
Min Flow	Press \blacktriangleright and enter a minimum flow cutoff. Forward and reverse flows less than Min Flow will be forced to zero.
Signal Cutoff	Adjust the setting in percent to suppress flow readings at zero flow when fluid swirling or pipe vibration may cause the instrument to continue reading. Example: Signal Cutoff at 5% will force the display and outputs to zero when signal strength drops below 5%.
LOS Time	Selectable from 0-99 seconds, default of 10, the LOS Time controls how long the Signal Strength must be below the Signal Cutoff before the reading on the DFM 6.1 goes to zero. This parameter is used to suppress sudden losses of signal which might be caused by a partially empty pipe, or cleaner fluids flowing by the sensor.

DFM 6.1 INSTRUCTION MANUAL

Calibra	ation
▶ Mode	Flow
20 mA	500 USG/ m
4 mA	0 USG/ m
MinFlow	5.00 USG/m
Signal C	utoff 10%
Damping	
Mode	FIR
Percent	10%
Window	1.0 ft/s
PipeID	4.03 i n
Cal Cons	tant 1.000

CALIBRATION (cont.)

Damping	Choose between OFF, FIR (Default), or LOW PASS.
Mode	When measured flows are outside the Window of the running average, the FIR filter will reduce the damping average so that a fast response can be made to the sudden change in flow rate.
	The LOW PASS filter will ignore measured flow rates outside the Window, while holding the running average, until there are enough data points outside the Window to cause a step-response to the new measured value.
	While measured flows are within the Window of the running average, both the FIR and LOW PASS filter behave the same.
Percent	Higher percentages increase the number of measurements which are averaged together to produce a stable flow reading. Higher percentages also increase the time it takes for the meter to make a step-response to the measured flow rate outside the Window in the LOW PASS Mode.
Window	Defines the Window around the running average, in units of Velocity set in the Units/Mode menu. Measurements made inside the Window are added to the running average, and measurements outside the Window effect the response of the meter as described in the Mode section.
Pipe ID	Place the cursor under the digits and then \bigvee or \blacktriangle to change the numbers and decimal point. Pipe ID should be entered as the exact inside diameter of the pipe where the sensor is mounted. Refer to the Pipe Charts Appendix in this manual for inside diameter of common pipe types and sizes.
Cal Constant	Scales the velocity reading. Factory value is close to 1.000 for a SE4-A sensor.

Press ✓ to return to Menu Selections screen.

--Relay Parameters--▶Relay 1 Function Flow On 1000 USC/sm Off 0.000 USC/sm

RELAY PARAMETERS

Press \triangledown or \blacktriangle to position curser at Relay Parameters, and \triangleright to enter. Use \triangledown or \blacktriangle to position cursor before each menu item and \triangleright to enter. When settings are completed press \checkmark to store and \checkmark again to return to the Main Menu.

Relay	Press \blacktriangleright and \triangledown or \blacktriangle to select a corresponding relay number (2 relays are standard, 4 additional are optional).
Function	Press \blacksquare or \blacktriangle to select Off, On, Pulse or Flow.
Flow	On Highlight the numerals and press \triangledown or \blacktriangle to set digits to the required relay On set point.
	Off set digits to the required Off set point.
Direction	When flow is in the positive direction, the relay will be disengaged, when flow is negative, the relay engages. Note: Rev. Flow in the Special Functions menu must be ON or INVERT for this to work properly.
Pulse	Press ▼ and set digits to the flow volume increment required between relay pulses. Use this feature for remote samplers, chlorinators or totalizers. Minimum time between pulses is 2.25 seconds and pulse duration is 350 milliseconds.
	Return to Relay and change settings for each relay number.
	Press \checkmark to return to Menu Selections.
ON	Sets relay in energized state.

DFM 6.1 INSTRUCTION MANUAL

r	
Data Loggi	ng
▶Log Site ID	0
Mode	Flow
File Format	. L G2
Date Ma	y 18/2018
Time	11:27:40
Interval	10sec
	60 min
	30 min
	15 min
	10 min
	5 min
	2 min
	1 min
	30sec
Data Log	St op
	Start
	Delete

DATA LOGGING

Press \checkmark or \blacktriangle to position curser at Data Logging, and \triangleright to enter. Use \checkmark or \blacktriangle to position cursor before each menu item and \triangleright to enter. When settings are completed press \checkmark to store and \checkmark again to return to the Main Menu.

Log Site ID	Enter a number from 00 to 99. The site ID will become part of the downloaded file name to help distinguish downloads from different instruments. Press \checkmark to store the setting.
Mode	Select Velocity (e.g. ft/sec or m/sec) or Flow (e.g. USGPM or l/sec). Press \checkmark to store the setting.
File Format	Choose .LG2 to download data in .lg2 format for viewing on Greyline Logger Software. Choose .CSV to download data in .csv format for import directly to Excel. This menu option can be changed at any time without adversely affecting existing data.
Date	Press \blacktriangleright , and \blacktriangle or \blacktriangledown to scroll and select Month, Day and Year. Press \checkmark to store the setting.
Time	Press \blacktriangleright , and \blacktriangle or \blacktriangledown to select the current time in Hours, Minutes and Seconds. Press \checkmark to store the setting.
Interval	Press \blacktriangle or \checkmark to select the logging interval. Press \checkmark to store the setting. Pulsar Measurement recommends choosing an interval which will give you as much resolution as required and no more. Choosing too often of an interval for what is required will result in larger data files, which may take a long time to download to USB. Reference page 15 for specific download times. In critical installations, data should be downloaded often.
Data Log	Stop, Start or Delete the log file. Press \blacktriangle or \checkmark to select Delete and \checkmark to delete the log file. Press \blacktriangle or \checkmark to select Start and \checkmark to start the logger.

Important Note: You <u>MUST</u> Delete an old log and Start a new log <u>AFTER</u> having made changes to Log Site ID, Mode, Date, Time and/or Interval for those changes to be applied.

Important Note: Changing any of the parameters in the Units/Mode menu will start a new log. It is recommended that you Delete and start a new log after changing any Units/Mode settings.

RETRIEVING LOG FILE

Plug a USB Flash Memory Drive (one is included with the DFM 6.1) into the USB output port on the Panel of the meter. The instrument display will show the data download icon until the log file is transferred to the memory card. The USB flash drive may be removed when the icon for download successful appears.

Download file names will appear in this format:



Tag is set according to the Log Site ID entered in the instrument Data Logging menu.

Download letter will be A for the first download from an instrument. B for the second, then C etc. At the letter Z a - character will appear indicating that the maximum number of downloads for that instrument are on the USB flash drive. Older files can be erased or moved from the flash memory drive or a new memory drive can be used.

Note: Downloading files in .lg2 format will take approximately 35 seconds per 1% of internal log memory used.
 Downloading files in .csv format will take approximately 8 minutes per 1% of internal log memory used.

OPENING .LG2 FILES

Install Greyline Logger Software on your PC or laptop. Select File/Open/Instrument Log (.log) to open the log file from your USB flash drive. Greyline Logger Software is available for download on the Pulsar Measurement website, www.pulsarmeasurement.com/downloads. Data can also be converted to .CSV via Greyline Logger Software.

OPENING .CSV FILES

Use a datasheet program such as Microsoft Excel® to import data in a comma delimited format. Use Excel to manipulate or graph data.

Communicat	ion
Protocol	Modbus
Address	001
BPS	9600
Parity	Even
Stop Bits	1

COMMUNICATION (Optional)

Press $\mathbf{\nabla}$ or $\mathbf{\Delta}$ to position curser at Communication, and $\mathbf{\triangleright}$ to enter. Use $\mathbf{\nabla}$ or $\mathbf{\Delta}$ to position cursor before each menu item and \blacktriangleright to enter. When settings are completed press \checkmark to store and \checkmark again to return to the Main Menu.

MODBUS Protocol Information:

Transceiver:	2-wire, half-duplex
Data format:	8 Data Bits
Floating Point Byte	Order: ABCD
Termination:	Jumper JP1 selectable 120Ω resistor. TB1 & TB2 = OFF, TB2 & TB3 = ON
Biasing:	None



HART® (Highway Addressable Remote Transducer) Protocol Information:

HART Version:	7.0
Device Description Files:	DD files allow the user's handheld HART communicator to fully configure the DFM 6.1 Pulsar Measurement provides DD files for the Emerson 475 Communicator. The files are included in the USB drive provided with your DFM 6.1 meter. You may also request the files from Pulsar Measurement by calling or emailing us at info@pulsarmeasurement.com.
	Warning : The DFM 6.1 and associated DDs are pending certification from the Fieldcomm Group.
Connections:	HART Protocol uses a digital signal superimposed on the 4-20mA output. When the 4-20mA output of the DFM 6.1 is connected with a load resistor (230 Ω to 600 Ω), the HART communicator can be connected on the loop in order to communicate.
Protocol	Choose MODBUS or HART.

20

Communicat	ion
Protocol	Modbus
Address	001
BPS	9600
Parity	Even
Stop Bits	1

COMMUNICATION (Optional) cont.

Address (Modbus)	Device address for the DFM. Valid range: 001-247 (Default: 001). This number should be unique across the bus. Press \blacktriangle or \blacktriangledown to scroll, \blacktriangleright to select digits, and press \checkmark to store the setting.
BPS (Modbus)	Baud rate for the MODBUS communications. Press \blacktriangle or \blacktriangledown to select, and \checkmark to store the setting. Options: 4800, 9600, 19200, 38400, 57600, 76800, and 115200 (Default: 9600).
Parity (Modbus)	Error checking parity for the MODBUS communications. Press \blacktriangle or \blacktriangledown to select, and \checkmark to store the setting. Options: None, Even, and Odd (Default: Even).
Stop Bits (Modbus)	Press \blacktriangle or \blacktriangledown to select, and \checkmark to store the setting. Options: 1 or 2 (Default: 1).

DFM 6.1 INSTRUCTION MANUAL

Special Functi	ons-
▶Language Eng	lish
Analog Out 4-	20 mA
Backlight	High
Reset Totalizer	NO
Neg. Totals	No
Rev. Flow	Of f
Capture Par	No
Capture WF	No
Restore Defaults	No
New Password	0000

SPECIAL FUNCTIONS

Language	Select English, French or Spanish
Analog Out	Select 4-20mA or 0-5V mode for the analog output.
Backlight	Select High, Medium or Low for continuous backlight.
	Select Key Hi/Lo for high backlight for 1 minute after a keypress and then Lo backlight until a key is pressed again.
	Select Key High, Med or Low for backlight for 1 minute after a keypress and then backlight off until a key is pressed again.
Reset Totalizer	Press \blacktriangleright and select Yes to erase and restart the totalizer at zero.
Neg. Totals	Select Yes to have reverse flow readings deducted from the totalizer. Select No to totalize forward flow only and ignore reverse flow
Rev. Flo	Select On to enable flow direction measurement. Select Off to disable flow direction measurement. Select Invert to invert the sense of the flow measurement.
Capture Par	This function captures the programming parameters in the meter. Select Yes, wait for Insrt USB to appear, then insert a USB drive into the USB port to transfer the parameters. After Saving flashes, Done will appear on the screen, meaning it is safe to remove the USB.

Special Functi	ons-
▶Language Eng	lish
Analog Out 4-	20 mA
Backlight	High
Reset Totalizer	NO
Neg. Totals	No
Rev. Flow	Of f
Capture Par	No
Capture WF	No
Restore Defaults	s No
New Password	0000
[

SPECIAL FUNCTIONS (cont.)

Capture WF	This function should only be used when instructed by a Pulsar Measurement representative to do so. The function captures the ultrasonic signal so that it can be evaluated by Pulsar Measurement.	
	Select Yes to start the waveform download process. After pressing Yes , the screen will flash Working for approximately 20 seconds, until the message Insrt USB appears. When Insrt USB is on the screen, connect a flash drive to the USB port on the front of the meter. The screen will flash Saving for a couple seconds, and then return to Done . The waveform is now stored on your flash drive and ready to be sent to Pulsar Measurement.	
Restore Defaults	Select Yes and press \checkmark to erase all user settings and return the instrument to factory default settings.	
New Password	Select any number from 0000 to 9999 and press ✓. Default setting of 0000 will allow direct access to the calibration menus. Setting of any password greater than 0000 will require the password to be entered to access the calibration menus.	

Press√to return to Menu Selections.

DFM 6.1 INSTRUCTION MANUAL

Simulation	1
▶Test	Actual
Flow	250USG m
4-20mAFlow	5.60
Relays 12	3456

SIMULATION

Press \checkmark or \blacktriangle to position curser at Simulation, and \triangleright to enter. Use \checkmark or \bigstar to position cursor before each menu item and \triangleright to enter. When settings are completed press \checkmark to store and \checkmark again to return to the Main Menu.

Changes made in the Simulation menu exercise the 4-20mA output, digital display and control relays.

Simulate a Flow /Velocity reading. Press \blacktriangleright and then \blacktriangledown or \blacktriangle to change the simulated output. Press \checkmark to begin simulation. The 4-20mA output and relay states will be displayed on the screen below.

Press the \checkmark to terminate simulation and return to the Menu Selections screen.

SENSOR MOUNTING LOCATION

The position of the sensor is one of the most important considerations for accurate flow measurement. The same location guidelines apply to Doppler as most other types of flow meters.

VERTICAL OR HORIZONTAL PIPE - Vertical pipe runs generally provide evenly distributed flow. On Horizontal pipes and liquids with high concentrations of gas or solids, the sensor should be mounted on the side (3 or 9 o'clock position) to avoid concentrations of gas at the top of the pipe, or solids at the bottom. For liquids with minimal gas bubbles (e.g. potable water) the sensor should be mounted on the top of a horizontal pipe (12 o'clock position) to obtain the best signal strength.



5 Dia	+	10 Dia	-
FLOW			

STRAIGHT RUN REQUIREMENTS – For best results, the transducers must be installed on a straight run of pipe, free of bends, tees, valves, transitions, insertion probes and obstructions of any kind. For most installations, ten straight unobstructed pipe diameters upstream and five diameters downstream of the transducers is the minimum recommended distance for proper operation. Additional considerations are outlined below.

- Do not, if possible, install the transducers downstream from a throttling valve, a mixing tank, the discharge of a positive displacement pump or any other equipment that could possibly aerate the liquid. The best location will be as free as possible from flow disturbances, vibration, sources of heat, noise, or radiated energy.
- Avoid mounting the transducers on a section of pipe with any external scale. Remove all scale, rust, loose paint, etc., from the location prior to mounting the transducers.
- Do not mount the transducers on a surface aberration (pipe seam, etc.).
- Do not mount transducers from different ultrasonic flow meters on the same pipe.
- Do not run the transducer cable in common bundles with cables from other instrumentation. You can run these cables through a common conduit ONLY if they originate at the same flow meter.
- Never mount transducers under water.

IMPORTANT NOTE: In some cases, longer straight runs may be necessary where the transducers are placed downstream from devices which cause unusual flow profile disruptions or swirl. For example: modulating valves, or two elbows in close proximity and out of plane.

SENSOR MOUNTING

Prepare an area 2" wide by 4" long (50mm x 100mm) for sensor bonding by removing loose paint, scale and rust. The objective of site preparation is to eliminate any discontinuity between the sensor and the pipe wall, which would prevent acoustical coupling.

A PC4 Sensor Mounting Kit is supplied with each flow meter. It includes recommended coupling compound and a stainless steel mounting bracket with adjustable pipe straps.



SENSOR COUPLING

For permanent or temporary bonding, the following are recommended:

a) Super Lube ® (supplied)

Additional supply: order Option CC-SL30 or your local home improvement store.

- b) Electrocardiograph gel
- c) Petroleum gel (Vaseline)

The above are arranged in their order of preferred application.

b & c are only good for temporary bonding at room temperature.

DO NOT USE: Silicon RTV caulking compound (silicon rubber).



Use the PC4 pipe clamp (supplied) as illustrated on the previous page. Apply Super Lube ® to the colored face of the sensor. A bead, similar to toothpaste on a toothbrush, is ideal. Do not overtighten (crush the sensor).

The sensor must be fixed securely to the pipe with coupling material between the sensor face and the pipe. Sensor installation with excessive coupling compound can result in gaps or voids in the coupling and cause errors or loss of signal. Insufficient coupling compound will create similar conditions.



Over time temporary coupling compounds (e.g. Petroleum Gel) may gradually sag away from the sensor resulting in reduced signal strength and finally complete loss of signal. Warm temperatures, moisture and vibration will accelerate this process. Super Lube ® as supplied with the DFM 6.1 (and available from Pulsar Measurement or home improvement stores) is recommended for semi-permanent installations.

SENSOR MOUNTING/COUPLING RECOMMENDATIONS



ENCLOSURE INSTALLATION

Locate the enclosure within 20 ft (6 m) of the sensor (500 ft -150 m optional). The enclosure can be wall mounted with the four mounting screws (included) or panel mounted with Option PM Panel Mount kit from Pulsar Measurement.

Avoid mounting the enclosure in direct sunlight to protect the electronics from damage due to overheating and condensate. In high humidity atmospheres, or where temperatures fall below freezing, Option TH Enclosure Heater and Thermostat is recommended. **IMPORTANT**: Seal conduit entries to prevent moisture from entering enclosure.

NEMA4X (IP66) WITH CLEAR COVER

1. Open hinged enclosure cover.

2. Insert #12 screws (supplied) through the four enclosure mounting holes to secure the enclosure to the wall or mounting stand.

Additional conduit holes can be cut in the bottom of the enclosure when required. Use a hole saw or Greenlee-type hole cutter to cut the required holes.

DO NOT make conduit/wiring entries into the top of the enclosure.



END VIEW



Note: This non-metallic enclosure does not automatically provide grounding between conduit connections. Grounding must be provided as part of the installation. Ground in accordance with the requirements of the National Electrical Code. System grounding is provided by connecting grounding wires from all conduit entries to the steel mounting plate or another point which provides continuity.

CLEANING

Cleaning is not required as a part of normal maintenance.

FIELD TROUBLESHOOTING **CORRECTIVE ACTION: POSSIBLE CAUSES:** METER READING LOWER THAN EXPECTED **Calibration Error** Review UNITS/MODE menu and Pipe ID • Investigate pump/valves. Compare velocity • with alternate instrument Lower flow rate than expected • Check "Cal Constant" in Special Functions menu. • Reinstall Sensor with careful application of Improper mounting of sensor **Coupling Compound** Pipe is not full Remount Sensor on vertical pipe • METER READING WHEN THERE IS NO FLOW • Adjust Signal Cutoff in Calibration Menu Ensure all Flowmeter wiring is in METAL • conduit and sensor shield is properly grounded. Local electrical noise Ensure correct power input Ground • connection (<1 ohm resistance). • Ensure 4-20mA Shield connected to Instrument Ground stud. Cross talk between two or more DFM 6.1 Refer to Synchronization instructions ٠ flowmeters on same pipe • Follow Drive manufacturers wiring and Grounding instructions Variable Speed Drive interference • Relocate Flowmeter electronics, Sensor and wiring away from VSD • Refer to Connections diagram. Disconnect and reconnect sensor cables ensuring that cable is properly inserted into terminals and tightened.

Sensor cable connections incorrect or loose

METER READING ERRATIC

Change sensor placement. Recommended 6-•

Sensor mounted too close to valve, pump or elbow

10 diameters from elbows, and 30 diameters from pumps, controlling valves, orifice plates, nozzles or open pipe discharge

POSSIBLE CAUSES:	CORRECTIVE ACTION:
NO FLOW INDICATION	
Not enough suspended particles or gases in the fluid	 Relocate sensor in more turbulent pipe section. Mount sensor at 12 o'clock position on horizontal pipe
Coupling compound washed out, or sensor loose on pipe	 Remount sensor Use Super Lube [®]
Power interruption. No flow.	Check fuse/breaker. Confirm flow
METER READING TOO HIGH	
Calibration error	• Review UNITS/MODE menu and Pipe ID
Pipe is not full	Remount Sensor on vertical pipe
Nearby velocity increasing device (pump, valve, orifice plate)	 Relocate sensor >30 pipe diameters from velocity increasing device
Local electrical noise	 Ensure all Flowmeter wiring is in METAL conduit and sensor cable shield is connected to Ground stud
Variable Speed Drive interference	 Follow Drive manufacturers wiring and Grounding instructions Relocate Flowmeter electronics, Sensor and wiring away from VSD
METER READING DOES NOT TRACK FLOW	
Sensor and GND wires reversed or not properly connected	Check Sensor connections
Improper AC power input Ground	• Use direct connection with 12 AWG wire to

Improper AC power input Ground

nearest Ground pole (<1 ohm resistance).

SENSOR CABLE RESISTANCE TEST

Unplug the green sensor terminal from the Doppler board and connect the sensor wires as shown. With a multimeter, perform resistance checks for each set of wires. One single loose terminal may cause false readings.

Test across shield and core of each wire: TMTR (black/white) and RCVR (black). Resistance should be around 82.5K ohms for any cable length. High readings indicate an open circuit and low readings indicate a short or partial short in the sensor cable.



COMMON QUESTIONS AND ANSWERS

The pipe vibrates. Will it affect the flow meter?

Common vibration frequencies are far lower than the sonic frequencies used by the flow meter and will not normally affect accuracy or performance. However, applications where very weak Doppler signal is present (when sensitivity is adjusted to maximum and signal strength is low), accuracy may be affected by pipe vibration, or the flow meter may show readings under no-flow conditions. Attempt to relocate the sensor on a pipe section where vibration is reduced, or arrange pipe mounting brackets to reduce vibration at the sensor mounting location.

The flow meter must be installed in a high noise environment. Will this affect operation?

Our flow meters are designed to discriminate between environmental noise and the Doppler signal. High noise environments may affect the flow meter's performance where low signal strength and/or low flow velocities are being measured.

Will pipe corrosion affect accuracy of the flow meter?

Yes. Rust, loose paint etc. must be removed from the outside of the pipe to provide a clean mounting position when installing a Doppler sensor. Severe corrosion/oxidation on the inside of the pipe may prevent the Doppler signal from penetrating into the flow. If the pipe cannot be cleaned, a spool piece (PVC recommended) should be installed for sensor mounting.

What effect do pipe liners have on the flow meter?

The air gap between loose insertion liners and the pipe wall prevent the Doppler signal from entering the flow. Better results can be expected with bonded liners such as cement, epoxy or tar, however an on site test is recommended to determine if the application is suitable for a Doppler flow meter.

Why is Doppler only recommended for liquids containing suspended solids or gases?

The Doppler sensor transmits sound into the flow stream which must be reflected back to the sensor to indicate flow velocity. Gas bubbles or suspended solids act as reflectors for the Doppler signal. As a guideline, our Doppler flow meters are recommended for liquids containing solids or bubbles with a minimum size of 100 microns and a minimum concentration of 75 ppm. Most applications (except potable, distilled or deionized water) will meet this minimum requirement.

Can the sensor be submerged in water?

Yes, for short periods of time or by accident, but it is not recommended for continuous operation. The sensor is constructed to withstand submersion to 10 psi without damage, but external liquid moving in contact with the sensor can be interpreted as flow and cause false readings.

What is the purpose of the Signal Strength Display?

Doppler signals of very low strength are not accepted or processed by the instrument. This feature assists in rejection of environmental noise and vibration. Use the display to evaluate signal strength in your application. Strong signals will increase in percentage to a maximum of 100% or greater.

DFM 6.1 INSTRUCTION MANUAL

Yes. Our Doppler's design allow cable lengths up to 500 ft (152 m) with no loss of signal strength. Extended cable (Option DXC) should be installed in rigid or flexible conduit for mechanical protection. Use only our shielded coaxial pair (RG174U) cable. Cable junctions should be made through a terminal block and housed in a watertight metal junction box (Option 'JB2X'). BNC coaxial connectors (TV cable type) are not recommended for cable splices.

Does the DFM 6.1 require periodic recalibration?

DFM 6.1 calibration does not drift over time. The solid-state sensor has no moving parts to wear and affect calibration. The Doppler flow technique generates an ultrasonic signal proportional to the velocity of flow. All timing/counting circuits use crystal-controlled frequency references to eliminate any drift in the processing circuitry.

ISO 9000 or similar quality management systems may require periodic and verifiable recalibration of flow meters. DFM 6.1 Doppler Flow Meters may be returned to Pulsar Measurement for factory calibration and issue of a new NIST traceable certificate. Refer to the 'Product Return Procedure' section of this manual for return instructions.

APPLICATIONS HOTLINE

For applications assistance, advice or information on any Pulsar Measurement Instrument contact your Sales Representative, write to Pulsar Measurement or phone the Applications Hotline below:

COUNTRY	TEL	FAX	E-MAIL	ADDRESS
United	315-788-9500	315-764-0419	northamerica@pulsarmeasurement.com	11451 Belcher Road South
States				Largo, FL 33773
Canada	613-938-8956	613-938-4857	northamerica@pulsarmeasurement.com	16456 Sixsmith Drive
				Long Sault, Ont. K0C 1P0
UK	+44 (0) 1684 891371	+44 (0) 1684 575985	europe@pulsarmeasurement.com	Cardinal Building
				Enigma Commercial Centre
				Sandy's Road, Malvern
				WR14 1JJ
Asia	N/A	N/A	asiapacific@pulsarmeasurement.com	34-1A, Jalan 10A/KU5
				Taman Aman Perdana
				41050 Klang, Selangor, Malaysia
Oceania	+61 428 692 274	N/A	<u>oceania@pulsarmeasurement.com</u>	N/A

PRODUCT RETURN PROCEDURE

Instruments may be returned to Pulsar Measurement for service or warranty repair.

1 Obtain an RMA Number from Pulsar Measurement -

Before shipping a product to the factory please contact Pulsar Measurement by telephone, fax or email to obtain an RMA number (Returned Merchandise Authorization). This ensures fast service and correct billing or credit.

When you contact Pulsar Measurement please have the following information available:

- 1. Model number / Software Version
- 2. Serial number
- 3. Date of Purchase
- 4. Reason for return (description of fault or modification required)
- 5. Your name, company name, address and phone number

2 Clean the Sensor/Product -

Important: unclean products will not be serviced and will be returned to the sender at their expense.

- 1. Rinse sensor and cable to remove debris.
- 2. If sensor has been exposed to sewage, immerse both sensor and cable in a solution of 1 part household bleach (Javex, Clorox etc.) to 20 parts water for 5 minutes. Important: do not immerse open end of sensor cable.
- 3. Dry with paper towels and pack sensor and cable in a sealed plastic bag.
- 4. Wipe the outside of the enclosure to remove dirt or deposits.
- 5. Return to Pulsar Measurement for service.

LIMITED WARRANTY

Pulsar Measurement warrants, to the original purchaser, its products to be free from defects in material and workmanship for a period of two years from date of invoice. Pulsar Measurement will replace or repair, free of charge, any Pulsar product if it has been proven to be defective within the warranty period. This warranty does not cover any expenses incurred in the removal and re-installation of the product.

If a product manufactured by Pulsar should prove defective within the first year, return it freight prepaid to Pulsar Measurement along with a copy of your invoice.

This warranty does not cover damages due to improper installation or handling, acts of nature, or unauthorized service. Modifications to or tampering with any part shall void this warranty. This warranty does not cover any equipment used in connection with the product or consequential damages due to a defect in the product.

All implied warranties are limited to the duration of this warranty. This is the complete warranty by Pulsar Measurement and no other warranty is valid against Pulsar Measurement. Some states do not allow limitations on how long an implied warranty lasts or limitation of incidental or consequential damages, so the above limitations or exclusions may not apply to you.

This warranty gives you specific legal rights, and you may also have other rights which vary from state to state.

Pulsar Measurement
OPTIONS

EXTRA SENSOR CABLE (OPTION DXC)

Each flow meter includes 25 ft / 7.6m (or 50 ft / 15m or 100 ft / 30m optional) continuous shielded coaxial pair cable. Additional cable and Cable Junction Box (Option JB2X) may be ordered to extend cable up to 500 ft (152m) as required during installation. No adjustment is required when the sensor cable is extended or shortened. IMPORTANT: Use only our shielded coaxial pair (RG174U) cable.

Extended sensor cable should be installed in conduit for mechanical protection. Recommended installation is illustrated below:



COAXIAL CABLE PREPARATION

DXC Doppler sensor cable can be cut and spliced up to a maximum length of 500 ft (152 m). Cable ends must be prepared as illustrated below.



SENSOR CABLE JUNCTION BOX (OPTION JB2X)

Optional Watertight steel NEMA4 Junction Boxes with terminal strips are available from Pulsar Measurement.



Velocity Sensor QZ02L-B (Optional)

Minimum Velocity:	0.1 ft/sec (0.03 m/sec)
Maximum Velocity:	20 ft/sec (6.2 m/sec)
Operating Temperature:	5 to 150°F (-15 to 65°C)
Exposed Materials:	316SS
Sensor Cable:	25 ft. (7.6 m) submersible polyurethane jacket, shielded, 3 coaxial
Hazardous Rating:	CSA rated Intrinsically Safe Class I, Groups C,D, Class II, Groups E,F,G with optional Intrinsic Safety Barrier



ENCLOSURE HEATER AND THERMOSTAT - Option TH

Instruments can be factory-equipped with an Enclosure Heater and Thermostat or the module can be customerinstalled. The Thermostat is factory set to turn ON at 40°F (4.5°C) and OFF at 60°F (15.5°C). Power consumption is 15 Watts.



ENCLOSURE SUNSCREEN - Option SCR

Do not mount instrument electronics in direct sunlight. Overheating will reduce the life of electronic components and condensate may form during the heat/cool cycles and cause electrical shorts.

Note:

Exposure to direct sunlight can cause overheating and moisture condensation which will reduce the operating life of electronics.

Protect Instruments from direct sunlight with this iridite finished aluminum sun screen (Option SCR).

Seal conduit entries with caulking compound to further reduce moisture condensation.



DFM 6.1 INSTRUCTION MANUAL

POWER INPUT OPTION 9-32VDC

DFM 6.1 Flow Meters may be ordered factory-configured for 9-32VDC power input, or a 9-32VDC Power Input card can be installed in the place of the 100-240VAC card in the field.

QUICK BENCH TEST:

Connect Sensor as shown below, then Power. Test operation of the DFM 6.1 by holding the sensor in one hand and rubbing your thumb or fingers briskly across the face (plastic surface) of the sensor. Allow 15 seconds for the DFM 6.1 to process the signal and display a flow value.

CONNECTIONS:

POWER INPUT: Connect 9-32VDC to the + and - terminals. The Power Input GND terminal must be connected to the nearest Ground pole. A 1amp fuse in line is recommended.



MODBUS® COMMUNICATION

MODBUS[®] serial interface connections are made at the RS485 card's terminal block if your DFM 6.1 was ordered with this card, or if one was added after installation. Card location:



DFM 6.1 INSTRUCTION MANUAL

Transceiver: MODBUS Address (MAC address) range: BAUD rates:

Biasing: Flow Control: 2-wire, half-duplex 1-255 (Default: 001) 4800, 9600, 19200, 38400, 57600, 76800 or 115200 (Default: 9600) 8 None, Even, Odd (Default: Even) 1, 2 (Default: 1) 120 Ohms or none (Default: None) Jumper JP1 position 1 & 2 = OFF (No term) Jumper JP1 position 2 & 3 = ON (Term) None None



Termination Jumper Position

Function Codes Supported:
01 – Read Coil(s)
02 – Read Discreet Input(s)
04 – Read Input Register(s)
05 – Write Single Coil
06 – Write Single Register
15 – Write Multiple Coils
16 – Write Multiple Registers
17 – Report Slave ID

MODBUS® MEMORY MAP

Register Address	Description	Register Type	Data Range	Over Range	Read/ Write	Comments
1	Reset Volume	Coil	NA	NA	Read/	Turn coil ON (1) to reset total on DFM 6.1.
	Total				Write	Turn coil to OFF (0) once reset is complete.

Register Address	Description	Register Type	Data Range	Over Range	Read/ Write	Comments
10001	Pulse Output 1	Discreet	NA	NA	Read	(0) indicates pulse output is OFF or inactive.
	Status	Input				(1) indicates pulse output is ON or active.
10002	Pulse Output 2	Discreet	NA	NA	Read	(0) indicates pulse output is OFF or inactive.
	Status	Input				(1) indicates pulse output is ON or active.

Register Address	Description	Register Type	Format Type	Comments
30001	Flow Velocity - ft/s	Input Register	Floating Point Register (1 of 2)	
30002	Flow Velocity - ft/s	Input Register	Floating Point Register (2 of 2)	
30003	Flow Velocity - m/s	Input Register	Floating Point Register (1 of 2)	
30004	Flow Velocity - m/s	Input Register	Floating Point Register (2 of 2)	
30101	Flow Rate - GPM (USG/min)	Input Register	Floating Point Register (1 of 2)	
30102	Flow Rate - GPM (USG/min)	Input Register	Floating Point Register (2 of 2)	
30103	Flow Rate - L/sec	Input Register	Floating Point Register (1 of 2)	
30104	Flow Rate - L/ssec	Input Register	Floating Point Register (2 of 2)	
30105	Flow Rate - ft ³ /min	Input Register	Floating Point Register (1 of 2)	
30106	Flow Rate - ft ³ /min	Input Register	Floating Point Register (2 of 2)	
30107	Flow Rate - m ³ /hr	Input Register	Floating Point Register (1 of 2)	
30108	Flow Rate - m ³ /hr	Input Register	Floating Point Register (2 of 2)	
30109	Flow Rate - USG/sec	Input Register	Floating Point Register (1 of 2)	
30110	Flow Rate - USG/sec	Input Register	Floating Point Register (2 of 2)	
30111	Flow Rate - USG/hr	Input Register	Floating Point Register (1 of 2)	
30112	Flow Rate - USG/hr	Input Register	Floating Point Register (2 of 2)	
30113	Flow Rate - USG/day	Input Register	Floating Point Register (1 of 2)	

Register Address	Description	Register Type	Format Type	Comments
30114	Flow Rate - USG/day	Input Register	Floating Point Register (2 of 2)	
30115	Flow Rate - ft ³ /s	Input Register	Floating Point Register (1 of 2)	
30116	Flow Rate - ft ³ /s	Input Register	Floating Point Register (2 of 2)	
30117	Flow Rate - ft ³ /hr	Input Register	Floating Point Register (1 of 2)	
30118	Flow Rate - ft ³ /hr	Input Register	Floating Point Register (2 of 2)	
30119	Flow Rate - ft³/day	Input Register	Floating Point Register (1 of 2)	
30120	Flow Rate - ft³/day	Input Register	Floating Point Register (2 of 2)	
30121	Flow Rate - USMG/sec	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30122	Flow Rate - USMG/sec	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30123	Flow Rate - USMG/min	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30124	Flow Rate - USMG/min	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30125	Flow Rate - USMG/hr	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30126	Flow Rate - USMG/hr	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30127	Flow Rate - USMG/day	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30128	Flow Rate - USMG/day	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30129	Flow Rate - L/min	Input Register	Floating Point Register (1 of 2)	
30130	Flow Rate - L/min	Input Register	Floating Point Register (2 of 2)	
30131	Flow Rate - L/hr	Input Register	Floating Point Register (1 of 2)	
30132	Flow Rate - L/hr	Input Register	Floating Point Register (2 of 2)	
30133	Flow Rate - L/day	Input Register	Floating Point Register (1 of 2)	
30134	Flow Rate - L/day	Input Register	Floating Point Register (2 of 2)	
30135	Flow Rate - m ³ /sec	Input Register	Floating Point Register (1 of 2)	
30136	Flow Rate - m³/sec	Input Register	Floating Point Register (2 of 2)	
30137	Flow Rate - m³/min	Input Register	Floating Point Register (1 of 2)	
30138	Flow Rate - m³/min	Input Register	Floating Point Register (2 of 2)	
30139	Flow Rate - m³/day	Input Register	Floating Point Register (1 of 2)	

Register Address	Description	Register Type	Format Type	Comments
30140	Flow Rate - m³/day	Input Register	Floating Point Register (2 of 2)	
30141	Flow Rate - IG/sec	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30142	Flow Rate - IG/sec	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30143	Flow Rate - IG/min	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30144	Flow Rate - IG/min	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30145	Flow Rate - IG/hr	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30146	Flow Rate - IG/hr	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30147	Flow Rate - IG/day	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30148	Flow Rate - IG/day	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30149	Flow Rate - IMG/sec	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30150	Flow Rate - IMG/sec	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30151	Flow Rate - IMG/min	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30152	Flow Rate - IMG/min	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30153	Flow Rate - IMG/hr	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30154	Flow Rate - IMG/hr	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30155	Flow Rate - IMG/day	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30156	Flow Rate - IMG/day	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30157	Flow Rate - bbl/sec	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30158	Flow Rate - bbl/sec	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30159	Flow Rate - bbl/min	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30160	Flow Rate - bbl/min	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30161	Flow Rate - bbl/hr	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30162	Flow Rate - bbl/hr	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30163	Flow Rate - bbl/day	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30164	Flow Rate - bbl/day	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons

Register Address	Description	Register Type	Format Type	Comments
30165	Previous day Average Flow Rate - GPM (USG/min)	Input Register	Floating Point Register (1 of 2)	
30166	Previous day Average Flow Rate - GPM (USG/min)	Input Register	Floating Point Register (2 of 2)	
30167	Previous day Average Flow Rate - L/sec	Input Register	Floating Point Register (1 of 2)	
30168	Previous day Average Flow Rate - L/ssec	Input Register	Floating Point Register (2 of 2)	
30169	Previous day Average Flow Rate - ft3/min	Input Register	Floating Point Register (1 of 2)	
30170	Previous day Average Flow Rate - ft3/min	Input Register	Floating Point Register (2 of 2)	
30171	Previous day Average Flow Rate - m3/hr	Input Register	Floating Point Register (1 of 2)	
30172	Previous day Average Flow Rate - m3/hr	Input Register	Floating Point Register (2 of 2)	
30173	Previous day Average Flow Rate - USG/sec	Input Register	Floating Point Register (1 of 2)	
30174	Previous day Average Flow Rate - USG/sec	Input Register	Floating Point Register (2 of 2)	
30175	Previous day Average Flow Rate - USG/hr	Input Register	Floating Point Register (1 of 2)	
30176	Previous day Average Flow Rate - USG/hr	Input Register	Floating Point Register (2 of 2)	
30177	Previous day Average Flow Rate - USG/day	Input Register	Floating Point Register (1 of 2)	
30178	Previous day Average Flow Rate - USG/day	Input Register	Floating Point Register (2 of 2)	
30179	Previous day Average Flow Rate - ft3/s	Input Register	Floating Point Register (1 of 2)	
30180	Previous day Average Flow Rate - ft3/s	Input Register	Floating Point Register (2 of 2)	
30181	Previous day Average Flow Rate - ft3/hr	Input Register	Floating Point Register (1 of 2)	
30182	Previous day Average Flow Rate - ft3/hr	Input Register	Floating Point Register (2 of 2)	
30183	Previous day Average Flow Rate - ft3/day	Input Register	Floating Point Register (1 of 2)	
30184	Previous day Average Flow Rate - ft3/day	Input Register	Floating Point Register (2 of 2)	
30185	Previous day Average Flow Rate - USMG/sec	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30186	Previous day Average Flow Rate - USMG/sec	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30187	Previous day Average Flow Rate - USMG/min	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons

Register Address	Description	Register Type	Format Type	Comments
30188	Previous day Average Flow Rate - USMG/min	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30189	Previous day Average Flow Rate - USMG/hr	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30190	Previous day Average Flow Rate - USMG/hr	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30191	Previous day Average Flow Rate - USMG/day	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30192	Previous day Average Flow Rate - USMG/day	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30193	Previous day Average Flow Rate - L/min	Input Register	Floating Point Register (1 of 2)	
30194	Previous day Average Flow Rate - L/min	Input Register	Floating Point Register (2 of 2)	
30195	Previous day Average Flow Rate - L/hr	Input Register	Floating Point Register (1 of 2)	
30196	Previous day Average Flow Rate - L/hr	Input Register	Floating Point Register (2 of 2)	
30197	Previous day Average Flow Rate - L/day	Input Register	Floating Point Register (1 of 2)	
30198	Previous day Average Flow Rate - L/day	Input Register	Floating Point Register (2 of 2)	
30199	Previous day Average Flow Rate - m3/sec	Input Register	Floating Point Register (1 of 2)	
30200	Previous day Average Flow Rate - m3/sec	Input Register	Floating Point Register (2 of 2)	
30201	Previous day Average Flow Rate - m3/min	Input Register	Floating Point Register (1 of 2)	
30202	Previous day Average Flow Rate - m3/min	Input Register	Floating Point Register (2 of 2)	
30203	Previous day Average Flow Rate - m3/day	Input Register	Floating Point Register (1 of 2)	
30204	Previous day Average Flow Rate - m3/day	Input Register	Floating Point Register (2 of 2)	
30205	Previous day Average Flow Rate - IG/sec	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30206	Previous day Average Flow Rate - IG/sec	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30207	Previous day Average Flow Rate - IG/min	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30208	Previous day Average Flow Rate - IG/min	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30209	Previous day Average Flow Rate - IG/hr	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30210	Previous day Average Flow Rate - IG/hr	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30211	Previous day Average Flow Rate - IG/day	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons

Register Address	Description	Register Type	Format Type	Comments
30212	Previous day Average Flow Rate - IG/day	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30213	Previous day Average Flow Rate - IMG/sec	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30214	Previous day Average Flow Rate - IMG/sec	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30215	Previous day Average Flow Rate - IMG/min	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30216	Previous day Average Flow Rate - IMG/min	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30217	Previous day Average Flow Rate - IMG/hr	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30218	Previous day Average Flow Rate - IMG/hr	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30219	Previous day Average Flow Rate - IMG/day	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30220	Previous day Average Flow Rate - IMG/day	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30221	Previous day Average Flow Rate - bbl/sec	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30222	Previous day Average Flow Rate - bbl/sec	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30223	Previous day Average Flow Rate - bbl/min	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30224	Previous day Average Flow Rate - bbl/min	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30225	Previous day Average Flow Rate - bbl/hr	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30226	Previous day Average Flow Rate - bbl/hr	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30227	Previous day Average Flow Rate - bbl/day	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30228	Previous day Average Flow Rate - bbl/day	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30301	Volume Total - Gallons	Input Register	Floating Point Register (1 of 2)	
30302	Volume Total - Gallons	Input Register	Floating Point Register (2 of 2)	
30303	Volume Total - Liters	Input Register	Floating Point Register (1 of 2)	
30304	Volume Total - Liters	Input Register	Floating Point Register (2 of 2)	
30305	Volume Total - ft ³	Input Register	Floating Point Register (1 of 2)	
30306	Volume Total - ft ³	Input Register	Floating Point Register (2 of 2)	
30307	Volume Total - m ³	Input Register	Floating Point Register (1 of 2)	
30308	Volume Total - m³	Input Register	Floating Point Register (2 of 2)	

Register Address	Description	Register Type	Format Type	Comments
30309	Volume Total - USMG	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30310	Volume Total - USMG	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30311	Volume Total - IG	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30312	Volume Total - IG	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30313	Volume Total - IMG	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30314	Volume Total - IMG	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30315	Volume Total - bbl	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30316	Volume Total - bbl	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30317	Previous day Volume Total - Gallons	Input Register	Floating Point Register (1 of 2)	
30318	Previous day Volume Total - Gallons	Input Register	Floating Point Register (2 of 2)	
30319	Previous day Volume Total - Liters	Input Register	Floating Point Register (1 of 2)	
30320	Previous day Volume Total - Liters	Input Register	Floating Point Register (2 of 2)	
30321	Previous day Volume Total - ft3	Input Register	Floating Point Register (1 of 2)	
30322	Previous day Volume Total - ft3	Input Register	Floating Point Register (2 of 2)	
30323	Previous day Volume Total - m3	Input Register	Floating Point Register (1 of 2)	
30324	Previous day Volume Total - m3	Input Register	Floating Point Register (2 of 2)	
30325	Previous day Volume Total - USMG	Input Register	Floating Point Register (1 of 2)	USMG = US Million Gallons
30326	Previous day Volume Total - USMG	Input Register	Floating Point Register (2 of 2)	USMG = US Million Gallons
30327	Previous day Volume Total - IG	Input Register	Floating Point Register (1 of 2)	IG = Imperial Gallons
30328	Previous day Volume Total - IG	Input Register	Floating Point Register (2 of 2)	IG = Imperial Gallons
30329	Previous day Volume Total - IMG	Input Register	Floating Point Register (1 of 2)	IMG = Imperial Million Gallons
30330	Previous day Volume Total - IMG	Input Register	Floating Point Register (2 of 2)	IMG = Imperial Million Gallons
30331	Previous day Volume Total - bbl	Input Register	Floating Point Register (1 of 2)	bbl = US Oil Barrel = 42 Gallons
30332	Previous day Volume Total - bbl	Input Register	Floating Point Register (2 of 2)	bbl = US Oil Barrel = 42 Gallons
30901	Signal Strength - %	Input Register	Integer	0-100

Register Address	Description	Register Type	Format Type	Comments
30904	Run Hours	Input Register	Floating Point Register (1 of 2)	
30905	Run Hours	Input Register	Floating Point Register (2 of 2)	
30923	Sensor Status	Input Register	Index (0-10)	0 = Sensor Good 4 = Sensor Open 5 = Sensor Short 7 = Low Signal
30925	Logging Status	Input Register	Index (0-2)	0 = Stopped 1 = Active 2 = Full
30926	Logging Used - %	Input Register	Floating Point Register (1 of 2)	
30927	Logging Used - %	Input Register	Floating Point Register (2 of 2)	
30962	Confidence	Input Register	Integer	
30963	Direction	Input Register	Integer	
30964	Pot 1	Input Register	Integer	
30965	Peak to Peak	Input Register	Integer	
30966	Correlation Strength	Input Register	Integer	

		1		
30947	Velocity Units	Input Register	Index (0 to 1)	0 = Feet per Second 1 = Meter per Second
30948	Flow Units	Input Register	Index (0 to 31)	 0 = US Gallons per Minute 1 = Litres per Second 2 = Cubic Feet per Minute 3 = Cubic Meters per Hour 4 = US Gallons per Second 5 = US Gallons per Day 7 = Cubic Feet per Second 8 = Cubic Feet per Hour 9 = Cubic Feet per Day 10 = US Million Gallons per Minute 12 = US Million Gallons per Hour 13 = US Million Gallons per Day 14 = Litres per Minute 15 = Litres per Day 17 = Cubic Meters per Second 18 = Cubic Meters per Second 18 = Cubic Meters per Second 18 = Cubic Meters per Minute 19 = Cubic Meters per Day 20 = Imperial Gallons per Hour 21 = Imperial Gallons per Hour 23 = Imperial Gallons per Day 24 = Imperial Gallons per Day 24 = Imperial Million Gallons per Day 25 = Imperial Million Gallons per Day 26 = Imperial Million Gallons per Day 27 = Imperial Million Gallons per Day 28 = Barrels per Second 29 = Barrels per Minute 30 = Barrels per Hour 31 = Barrels per Day
30949	Linear Units	Input Register	Index (0 to 3)	0 = Feet 1 = Inches 2 = Millimeters 3 = Meters
30950	Volume Units	Input Register	Index (0 to 7)	0 = Cubic Feet 1 = US Gallons 2 = US Million Gallons 3 = Imperial Gallons 4 = Imperial Million Gallons 5 = Cubic Meters 6 = Litre 7 = Barrel
30951	Time Units	Input Register	Index (0 to 3)	0 = Second 1 = Minute 2 = Hour 3 = Day

HART® COMMUNICATION

HART® (Highway Addressable Remote Transducer) connections are made on the 4-20mA output of the DFM 6.1. The DFM 6.1 must be equipped with the optional serial communication card for the Communication menu to appear, and for the HART option to be able to be selected in the Communication menu. 4-20mA output location:



HART® (Highway Addressable Remote Transducer) Protocol Information:

7.0

HART Version:

Device Description Files:	DD files allow the user's handheld HART communicator to fully configure the DFM 6.1. Pulsar Measurement provides DD files for the Emerson 475 Communicator. The files are included in the USB drive provided with your DFM 6.1 meter. You may also request the files from Pulsar Measurement by calling or emailing us at info@pulsarmeasurement.com. Warning: The DFM 6.1 and associated DDs are pending certification from the Fieldcomm Group.
Connections:	HART Protocol uses a digital signal superimposed on the 4-20mA output.

onnections: HART Protocol uses a digital signal superimposed on the 4-20mA output. When the 4-20mA output of the DFM 6.1 is connected with a load resistor (230Ω to 600Ω), the HART communicator can be connected on the loop in order to communicate.

Loading the DD Files to the 475 Field Communicator

- 1. Install Emerson Field Communicator Easy Upgrade Utility from Emerson website
 - a. <u>http://www3.emersonprocess.com/ams/fieldcommunicatorsupport/</u>
- 2. Run Field Communicator Easy Upgrade utility.
- Locate the DD Files from the Pulsar Measurement USB drive included with the DFM 6.1.
 a. 6109E3FD0101.hdd
- 4. Make sure your PC software is up to date by clicking Update PC.

pgrade	Upgrad	e			Help
censing & Registration tilities	1. Update P	PC .			
ettings	Update	PC	Last updated: 7/13/2018 11:33:30).AM	More Details
ebsite	🖌 2. Connect	Field Communicat	or		
		-	Connected	To To	
		Connection type	Bluetooth	Deconnect	
	Unit Name:	None			More Details
	🖌 3. Upgrade	Field Communicat	or		
	Field Com	municator is up to d	late		More Options

DFM 6.1 INSTRUCTION MANUAL

- 5. Click on *Utilities* form the left menu pane.
- 6. Click on Import DDs from a local source.



7. A popup window is displayed as shown below. Navigate to the directory containing the DD files using the *Browse* button. Select the desired DD files that shows up for your HART device. Click *OK*.

Upgrade	Utilities		Help
Licensing & Registration	Select path to DD files		
Utilities	Location C:\FCMedia\SDIN\HART\DD	Browse	
Settings	HART: GREYLINE TTFM 6.1 Rev 1 DD 1 (en)		
Website			
		OK Cancel	

8. Navigate back to the previous screen by clicking on *Upgrade* from the left menu pain.

9. Under Connect Field Communicator, select the type of the connection your device utilizes. Then click *Connect*.

Field Communicator Easy Upgrad Upgrade	e Utility 3.6.1 Upgrade			- X
Licensing & Registration Utilities	1. Update PC			
Settings	Update PC	Last updated: 7/13/2018 11:33:30 AM		More Details
Website	📝 2. Connect Field Commu	inicator		
		Connected	8	
	Connection t	ype Bluetooth v	Disconnect	
	Unit Name: None			More Details
	📝 3. Upgrade Field Comm	unicator		
	Field Communicator is u	ip to date		Close Tabs View

10. Select Field Communicator from list shown below.

🗜 Field Communicator Easy Upgrade U	tility 3.6.1	- 🗆 X
Upgrade	Upgrade	Help
Licensing & Registration	Select Field Communicator	
Utilities	1. Upd: Select a Field Communicator from the list and click OK.	
Settings	Up Unit Name: None	More Details
Website	2. Conr	
	3 Ungr	
	Not cc Refresh OK Cancel	More Options

11. Once connected, click *More Options*. The *System Software* Tab Is now opened. Click the *DDs* tab.

Field Communicator Easy Upgrade	Utility 3.6.1			– 🗆 X
Upgrade	Upgrade			Help
Licensing & Registration Utilities	1. Update PC			
Settings	Update PC	Last updated: 7/13/2018 11:33:30 /	M	More Details
Website	📝 2. Connect Field Communica	ator		
		Connected		
	Connection type	Bluetooth	Disconnect	
	Unit Name: None			More Details
	📝 3. Upgrade Field Communic	ator		
	Field Communicator is up to	date		Close Tabs View
0.0.0.0.0.000	System Software DDs User Date	a Event Capture HART configuration		
	PC Database (English)	0/0.0 kB	Field Communicator	0/0.0 kB
	System Software: 1:1 (en) System Software: 1:4 (en)	^	System Software: 3:9 (en)	
nenero <u>ta e e</u>	System Software: 1:6 (en) System Software: 1:7 (en)			
	System Software: 1:8 (en)	>>>		
	System Software: 2:0 (en)			
	System Software: 2:3 (en)			
	System Software: 3:0 (en)	~		
	L]

12. The newly uploaded DD from the Utilities: Import DDs from Local source. Select the DD file you wish to send to the Field communicator. If package is untested, slect **Yes in the** *Check an untested package dialog box.*

🖁 Field Communicator Easy Upgrade	Utility 3.6.1	– 🗆 X
Upgrade	Upgrade	Help
Licensing & Registration	1. Update PC	
Utilities	Last updated: 7/13/2018 11:33:30 AM	
Settings	Update PC	More Details
Website	🖌 2. Connect Field Communicator	
		
	Connected	
	Line Name: Name	Mara Dataila
		More Details
	3. Upgrade Field Communicator Field Communicator is un to date	
法法法律 化二十		Close Tabs View
	System Software DDs User Data Event Capture HART configuration PC Database (English) 1/180.0 kB Field Communicator	0/0.0 kB
	GEORGIN GLI GLI GEORGIN Field Communicator Easy Upgrade Utility	×
	GREVINE Check an untested package?	
	GREVINE DFM 6.1 Rev 1 DD 1 (en)	
	Harold Beck and Sons	No
	Hawk	
	Select All Clear All Remove S	elect All Clear All

13. Click on the *Transfer Button (Button with 3 arrows/Chevrons facing right)*. Wait until download complete dialog appears, then close out or continue with program as needed.

rada	Upgrad	e			Help
ensing & Registration	1. Update f				
tings	Updale	PC	Last-gdated 7/15/2018	11.3330.44	More Detail
osite	2. Connect	Field Communicat	ior -		
		- 19	Connected	1 0	
		Connection type	Bluesson	- Decorrect	
	Unit Name.	Noce			More Detail
	Upgrading System Software	DOs User Date ane (English)	Event Capture HART cont 2/360.0 kB	fguration	or 6/0.048
	System Software	DOs User Date are (English) COEGIN	Event Capture HART cont 2/360.0 kB	fguration Red Communication	or Grūūkė
	System Schware	DOs User Date me (English) COEGIN 7 50 50	Event Capture HART cont 2/360.0.48	figuration Po Field Communication Pr HART Presidous	or 6/0.0.kB
	System Software	DOs User Date are (English) CORGIN 1-50 EYUNE GREVLINE DFM & LI Re GREVLINE TYTM & LI R	Event Capture HART cont 2/360.0kB	Tyuration P. Field Communicat P. HART B FieldSoux	or Grünke
	System Software PC Database PC PC P	DOS User Date me (English) IORGIN I ISOULINE I GREVLINE DFM & I Re GREVLINE TITM & I Re GREVLINE TITM & I Re GREVLINE TITM & I Re	Event Capture HART.com 2/360.0kB	Tguration Pried Communication Pried Communication	or Grūūkā
	System Software	DOs User Date are (English) CREGIN 1 530 GEVLINE GREVILINE TYPM 61 Re CREVILINE TYPM 70 RE CREVILINE T	Event Capture HART cont 2/360.0x8	fguration IIII Piel Communication IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	or D/D.D.B
	System Software	DOs User Date are (English) DeGini 1-30 GYUNE 0 GERVINE DFM & I Are GREVINE DFM & I Are CREVINE DFM & I ARE CREVENDA DFM & I AR	Event Capture HART cont 2/360.048 rv 100.1 (en) ex 100.1 (en) ex 100.1 (en)	fguration P. Reid Communication P. HART Presidoust Presidoust Presidoust	or D'OOLB

Device Descriptor Menu Structure

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6
Device Setup	Process Variables	PV			
		PV% Range			
		PV Loop Current			
		Dynamic Variables			
	Basic Setup	PV Unit			
		PV Xfer fnctn			
		PV Damp			
		Device Information	Distributor		
			Model		
			Dev id		
			Serial Number		
			Relay Count		
			Cfg chng count		
			Тад		
			Long Tag		
			Date		
			Write Protect		
			Descriptor		
			Message		
			Final asmbly num		
			Revision #'s		
			Device Image		
	Detailed Setup	Sensors	Flow Rate Sensor	Flow Rate	
				Flow Rate Unit	
				Sensor Information	Flow Rate Class
					Flow Rate PDQ
					Flow Rate LS

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6
					Flow Rate LSL
					Flow Rate USL
					Flow Rate Damp
			Velocity Sensor	Velocity	
				Velocity Unit	
				Sensor Information	Velocity Class
					Velocity PDQ
					Velocity LS
					Velocity LSL
					Velocity USL
					Velocity Damp
			Volume Sensor	Volume	
				Volume Unit	
				Sensor Information	Volume Class
					Volume PDQ
			Max dev vars		
		PV is			
		Signal condition	PV LRV		
			PV URV		
			PV % Range		
			PV Xfer fnctn		
			PV Damp		
		Output Condition	Analog Output	PV Loop Current	
				PV Alrm typ	
				PV Channel flags	
				Loop current mode	
			HART Output	Poll addr	

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6
				Num req preams	
				Num resp preams	
		Device Information	Distributor		
			Model		
			Dev id		
			Serial Number		
			Relay Count		
			Cfg chng count		
			Тад		
			Long Tag		
			Date		
			Write Protect		
			Descriptor		
			Message		
			Final asmbly num		
			Revision #'s		
			Device Image		
	Review	Model			
		Distributor			
		Write protect			
		Dev id			
		Serial Number			
		Relay Count			
		Cfg chng count			
		Max dev vars			
		Тад			
		Long tag			

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6
		Descriptor			
		Message			
		Date			
		Final asmbly num			
		Universal rev			
		Fld dev rev			
		Software rev			
		Hardware rev			
		Poll addr			
		Loop current mode			
		Num req preams			
		Num resp preams			
Status	Relay Count				
	Relay 1				
	Relay 2				
	Pri Sen Stat				
	Prim Read Quality				
	Device Status	Device Status			
		Cfg chng count			
		Reset Configuration			
	Dev Spec Stat 0	Status group 0			
	Dev Spec Stat 1	Status group 1			
	Dev Spec Stat 2	Status group 2			
	Dev Spec Stat 3	Status group 3			
	Dev Spec Stat 4	Status group 4			
	Dev Spec Stat 5	Status group 5			
	Ext Dev Stat	Ext dev status			

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6
Logging	Logger Options	Log Status			
		Log Mode			
		Percent Log Used			
PV					
PV Loop Current					
PV LVR					
PV URV					

APPENDIX A – Classified Area Installation Control Drawings

SESPEC-INST-01: SE4-A Certified CSA C/US Intrinsically Safe for Class I, Div 1, Groups C,D; Class II, Groups E,F,G; Class III





SESPEC-INST-02: SE4-A Certified CSA C/US Non-Incendive for Class 1 Div 2, Groups A,B,C,D

I-0043.01: SE4-A Certified ATEX/IECEx Ex ia for Zone 0, Gas group IIB



APPENDIX B – Specifications

	←7.4" / 188 mm ─	
±0.1 to 40 ft/sec, (±0.03 to 12.2 m/sec) in most	6.46"/ 164 mm →	← 5.12" / 130 mm →
applications Any pipe ID from ½ " to 180" (12.7 mm to 4.5 m)		
±2% of reading or 0.1 ft/sec (0.03 m/sec) whichever is greater Requires solids or bubbles minimum size of 100 microns, minimum	CONTROL CONTRO	→ 0.94"/ 278
concentration 75 ppm. Repeatability: ±0.1%, Linearity ±0.5%	CONDUIT ENTRY LOCATION	SIDE MEW
White, backlit matrix - displa 16-digit totalizer, relay state	ays flow rate, es, operating mode and	d calibration menu
built-in 5-key calibrator with selection	n English, French or Sp	anish language
100-240VAC, 50/60Hz, 10VA Optional: 9-32VDC, 10 watts	A maximum s maximum	
Isolated 4-20mA (1000 ohm	load max.)	
Qty 2, rated 5 amp 240VAC proportional pulse	SPDT, programmable	flow alarm and/or
Built-in 26 million point Log software	ger with USB output a	nd Windows [™]
watertight, dust tight NEMA shatter-proof face	4X (IP 66) polycarbona	ate with a clear
-10° to 140°F (-23° to 60°C)		
10 lbs (4.5 kg)		
	±0.1 to 40 ft/sec, (±0.03 to 12.2 m/sec) in most applications Any pipe ID from $\frac{1}{2}$ to 180" (12.7 mm to 4.5 m) ±2% of reading or 0.1 ft/sec (0.03 m/sec) whichever is greater Requires solids or bubbles minimum size of 100 microns, minimum concentration 75 ppm. Repeatability: ±0.1%, Linearity ±0.5% White, backlit matrix - displated 16-digit totalizer, relay stated built-in 5-key calibrator with selection 100-240VAC, 50/60Hz, 10V/ Optional: 9-32VDC, 10 watted Isolated 4-20mA (1000 ohm Qty 2, rated 5 amp 240VAC proportional pulse Built-in 26 million point Log software watertight, dust tight NEMA shatter-proof face -10° to 140°F (-23° to 60°C) 10 lbs (4.5 kg)	±0.1 to 40 ft/sec, (±0.03 to 12.2 m/sec) in most applications Any pipe ID from $\frac{1}{2}$ " to 180" (12.7 mm to 4.5 m) ±2% of reading or 0.1 ft/sec (0.03 m/sec) whichever is greater Requires solids or bubbles minimum size of 100 microns, minimum concentration 75 ppm. Repeatability: ±0.1%, Linearity ±0.5% White, backlit matrix - displays flow rate, 16-digit totalizer, relay states, operating mode and built-in 5-key calibrator with English, French or Sp selection 100-240VAC, 50/60Hz, 10VA maximum Optional: 9-32VDC, 10 watts maximum Isolated 4-20mA (1000 ohm load max.) Qty 2, rated 5 amp 240VAC SPDT, programmable proportional pulse Built-in 26 million point Logger with USB output a software watertight, dust tight NEMA4X (IP 66) polycarbonal shatter-proof face -10° to 140°F (-23° to 60°C) 10 lbs (4.5 kg)

SE4 Doppler Sensor

Minimum Pipe Diameter: Maximum Pipe Diameter: **Operating Temperature: Operating Frequency: Sensor Housing:** Sensor Cable:

0.5" (12.5 mm) 180" (4.5 m) -40° to 300°F (-40° to 150°C) 640 KHz **Stainless Steel** 25 ft. (7.6 m) shielded coaxial pair (RG174U) Optional 50 ft (15 m) or 100 ft (30 m) continuous Withstands accidental submersion pressure up to 10 psi (0.7 Bar)

Submersion Rating:



APPENDIX C – Conversion Table

CONVERSION GUIDE										
FROM	то	MULTIPLY BY								
US GALLONS	CUBIC FEET	0.1337								
US GALLONS	IMPERIAL GALS	0.8327								
US GALLONS	LITRES	3.785								
US GALLONS	CUBIC METERS	0.003785								
LITRES/SEC	GPM	15.85								
LITRES	CUBIC METERS	0.001								
BARRELS	US GALLONS	42								
BARRELS	IMPERIAL GALS	34.9726								
BARRELS	LITRES	158.9886								
INCHES	ММ	25.4								
DEGREES F	DEGREES C	(°F-32) x 0.556								
POUNDS	KILOGRAMS	0.453								
PSI	BAR	0.0676								
FOOT ²	METER ²	0.0929								

Note: BARRELS are U.S. oil barrels

APPENDIX D – Pipe Charts

Carbon Steel & PVC Pipe

Pine	Pine	Stand	dard ule 40	Extra Heavy Schedule 80		Dbi. Extra Heavy		Schedule 10		Schedule 20		Schedule 30		Schedule 40	
Size	0.D.	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL
1/2	.840	.622	.109	.546	.147	.252	.294							.622	.109
3/4	1.050	.824	.113	.742	.154	.434	.308							.824	.113
1	1.315	1.049	.133	.957	.179	.599	.358							1.049	.133
1¼	1.660	1.380	.140	1.278	.191	.896	.382							1.380	.140
11/2	1.900	1.610	.145	1.500	.200	1.100	.400							1.610	.145
2	2.375	2.067	.154	1.939	.218	1.503	.436							2.067	.154
21⁄2	2.875	2.469	.203	2.323	.276	1.771	.552							2.469	.203
3	3.500	3.068	.216	2.900	.300	2.300	.600							3.068	.216
31⁄2	4.000	3.548	.226	3.364	.318	2.728	.636							3.548	.226
4	4.500	4.026	.237	3.826	.337	3.152	.674							4.026	.237
5	5.563	5.047	.258	4.813	.375	4.063	.750							5.047	.258
6	6.625	6.065	.280	5.761	.432	4.897	.864							6.065	.280
8	8.625	7.981	.322	7.625	.500	6.875	.875			8.125	.250	8.071	.277	7.981	.322
10	10.750	10.020	.365	9.750	.500	8.750	1.000			10.250	.250	10.136	.307	10.020	.365
12	12.750	12.000	.375	11.750	.500	10.750	1.000			12.250	.250	12.090	.330	11.938	.406
14	14.000	13.250	.375	13.000	.500			13.500	.250	13.376	.312	13.250	.375	13.124	.438
16	16.000	15.250	.375	15.000	.500			15.500	.250	15.376	.312	15.250	.375	15.000	.500
18	18.000	17.250	.375	17.000	.500			17.500	.250	17.376	.312	17.124	.438	16.876	.562
20	20.000	19.250	.375	19.000	.500			19.500	.250	19.250	.375	19.000	.500	18.814	.593
22	22.000	21.250	.375	21.000	.500			21.500	.250	21.250	.375	21.000	.500		
24	24.000	23.250	.375	23.000	.500			23.500	.250	23.250	.375	22.876	.562	22.626	.687
26	26.000	25.250	.375	25.000	.500			25.376	.312	25.000	.500				
28	28.000	27.250	.375	27.000	.500			27.376	.312	27.000	.500	26.750	.625		
30	30.000	29.250	.375	29.000	.500			29.376	.312	29.000	.500	28.750	.625		
32	32.000	31.250	.375	31.000	.500			31.376	.312	31.000	.500	30.750	.625		
34	34.000	33.250	.375	33.000	.500			33.376	.312	33.000	.500	32.750	.625		
36	36.000	35.250	.375	35.000	.500			35.376	.312	35.000	.500	34.750	.625		
42	42.000	41.250	.375	41.000	.500					41.000	.500	40.750	.625		

Ductile Iron Pipe - Standard Classes

Size	OUTSIDE	Cla	SS	Cla	ISS	Cla	ISS	Cla	ISS	Cla	SS	Cla	ISS	Class		Class		CEMEN	LINING
INCH	DIA.	5	0	5	1	5	2	5	3	5	4	5	5	5	6	**S TD	** DOUB LE		
	INCH	WALL	LD.	WALL	LD.	WALL	LD.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	THICKNESS	THIC KN ESS		
3	3.96			025	3.46	0.28	3.40	0.31	3.34	0.34	3.28	0.37	3.22	0.41	3.14				
4	4.80			026	428	0.29	4.22	0.32	4.16	0.35	4.10	0.38	4.04	0.44	3.93				
6	6.90	0.25	6.40	028	6.34	0.31	6.28	0.34	6.22	0.37	6.16	0.40	6.10	0.43	6.04	.125	.250		
8	9.05	0.27	8.51	0.30	8.45	0.33	8.39	0.36	8.33	0.39	8.27	0.42	8.21	0.45	8.15				
10	11.10	0.39	10.32	0.32	10.46	0.35	10.40	0.38	10.34	0.41	10.28	0.44	10.22	0.47	10.16				
12	13.20	0.31	12.58	0.34	12.52	0.37	12.46	0.40	12.40	0.43	12.34	0.46	12.28	0.49	12.22				
14	15.30	0.33	14.64	0.36	14.58	0.39	14.52	0.42	14.46	0.45	14.40	0.48	14.34	0.51	14.28				
16	17.40	0.34	16.72	0.37	16.66	0.40	16.60	0.43	16.54	0.46	16.48	0.49	16.42	0.52	16.36				
18	19.50	0.35	18.80	0.38	18.74	0.41	18.68	0.44	18.62	0.47	18.56	0.50	18.50	0.53	18.44	.1875	.375		
20	21.60	0.36	20.88	0.39	20.82	0.42	20.76	0.45	20.70	0.48	20.64	0.51	20.58	0.54	20.52				
24	25.80	0.38	25.04	0.41	24.98	0.44	24.92	0.47	24.86	0.50	24.80	0.53	24.74	0.56	24.68				
30	32.00	0.39	31.22	0.43	31.14	0.47	31.06	0.51	30.98	0.55	30.90	0.59	30.82	0.63	30.74				
36	38.30	0.43	37.44	0.48	37.34	0.62	37.06	0.58	37.14	0.63	37.04	0.68	36.94	0.73	36.84				
42	44.50	0.47	43.56	0.53	43.44	0.59	43.32	0.65	43.20	0.71	43.08	0.77	42.96	0.83	42.84	.250	.500		
48	50.80	0.51	49.78	0.58	49.64	0.65	49.50	0.72	49.36	0.79	49.22	0.86	49.08	0.93	48.94				
54	57.10	0.57	55.96	0.65	55.80	0.73	55.64	0.81	55.48	0.89	55.32	0.97	55.16	1.05	55.00				

**REDUCE I.D. BY DIMENSION SHOWN

Pipe	Pipe	Sc	heule 5 S (a)	Sch	edule 10 S (a)	Scl	hedule 40 S	Sc	hedule 80 S
Size	O.D.	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL
1/2	.840	.710	.065	.674	.083	.622	.109	.546	.147
3/4	1.050	.920	.065	.884	.083	.824	.113	.742	.154
1	1.315	1.185	.065	1.097	.109	1.049	.133	.957	.179
1¼	1.660	1.530	.065	1.442	.109	1.380	.140	1.278	.191
11⁄2	1.900	1.770	.065	1.682	.109	1.610	.145	1.500	.200
2	2.375	2.245	.065	2.157	.109	2.067	.154	1.939	.218
21/2	2.875	2.709	.083	2.635	.120	2.469	.203	2.323	.276
3	3.500	3.334	.083	3.260	.120	3.068	.216	2.900	.300
31/2	4.000	3.834	.083	3.760	.120	3.548	.226	3.364	.318
4	4.500	4.334	.083	4.260	.120	4.026	.237	3.826	.337
5	5.563	5.345	.109	5.295	.134	5.047	.258	4.813	.375
6	6.625	6.407	.109	6.357	.134	6.065	.280	5.761	.432
8	8.625	8.407	.109	8.329	.148	7.981	.322	7.625	.500
10	10.750	10.482	.134	10.420	.165	10.020	.365	9.750	.500
12	12.750	12.438	.156	12.390	.180	12.000	.375	11.750	.500
14	14.000	13.688	.156	13.624	.188				
16	16.000	15.670	.165	15.624	.188				
18	18.000	17.670	.165	17.624	.188				
20	20.000	19.634	.188	19.564	.218				
22	22.000	21.624	.188	21.564	.218				
24	24.000	23.563	.218	23.500	.250				

Stainless Steel, Hastelloy "C" & Titanium Pipe

Pipe	Pipe	Schedule 60		Schedule 80		Schedule 100		Schedule 120		Schedule 140		Schedule 160	
Size	O.D.	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL
1/2	.840			.546	.147							.466	.187
3/4	1.050			.742	.154							.614	.218
1	1.315			.957	.179							.815	.250
1¼	1.660			1.278	.191							1.160	.250
1½	1.900			1.500	.200							1.338	.281
2	2.375			1.939	.218							1.689	.343
21/2	2.875			2.323	.276							2.125	.375
3	3.500			2.900	.300							2.624	.438
31/2	4.000			3.364	.318								
4	4.500			3.826	.337			3.624	.438			3.438	.531
5	5.563			4.813	.375			4.563	.500			4.313	.625
6	6.625			5.761	.432			5.501	.562			5.189	.718
8	8.625	7.813	.406	7.625	.500	7.439	.593	7.189	.718	7.001	.812	6.813	.906
10	10.750	9.750	.500	9.564	.593	9.314	.718	9.064	.843	8.750	1.000	8.500	1.125
12	12.750	11.626	.562	11.376	.687	11.064	.843	10.750	1.000	10.500	1.125	10.126	1.312
14	14.000	12.814	.593	12.500	.750	12.126	.937	11.814	1.093	11.500	1.250	11.188	1.406
16	16.000	14.688	.656	14.314	.843	13.938	1.031	13.564	1.218	13.124	1.438	12.814	1.593
18	18.000	16.500	.750	16.126	.937	15.688	1.156	15.250	1.375	14.876	1.562	14.438	1.781
20	20.000	18.376	.812	17.938	1.031	17.438	1.281	17.000	1.500	16.500	1.750	16.064	1.968
22	22.000	20.250	.875	19.750	1.125	19.250	1.375	18.750	1.625	18.250	1.875	17.750	2.125
24	24.000	22.064	.968	21.564	1.218	20.938	1.531	20.376	1.812	19.876	2.062	19.314	2.343

Cast Iron Pipe - ASA Standard

Pipe	Pipe	Clas	s 50	Class	s 100	Class	s 150	Clas	s 200	Class	s 250	Clas	s 300	Class	s 350
Size	O.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.	WALL	I.D.
3	3.96	0.32	3.32	0.32	3.32	0.32	3.32	0.32	3.32	0.32	3.32	0.32	3.32	0.32	3.32
4	4.80	0.35	4.10	0.35	4.10	0.35	4.10	0.35	4.10	0.35	4.10	0.35	4.10	0.35	4.10
6	6.90	0.38	6.14	0.38	6.14	0.38	6.14	0.38	6.14	0.38	6.14	0.38	6.14	0.38	6.14
8	9.05	0.41	8.23	0.41	8.23	0.41	8.23	0.41	8.23	0.41	8.23	0.41	8.23	0.41	8.23
10	11.10	0.44	10.22	0.44	10.22	0.44	10.22	0.44	10.22	0.44	10.22	0.48	10.14	0.52	10.06
12	13.20	0.48	12.24	0.48	12.24	0.48	12.24	0.48	12.24	0.52	12.16	0.52	12.16	0.56	12.08
14	15.30	0.48	14.34	0.51	14.28	0.51	14.28	0.55	14.20	0.59	14.12	0.59	14.12	0.64	14.02
16	17.40	0.54	16.32	0.54	16.32	0.54	16.32	0.58	16.24	0.63	16.14	0.68	16.04	0.68	16.04
18	19.50	0.54	18.42	0.58	18.34	0.58	18.34	0.63	18.24	0.68	18.14	0.73	18.04	0.79	17.92
20	21.60	0.57	20.46	0.62	20.36	0.62	20.36	0.67	20.26	0.72	20.16	0.78	20.04	0.84	19.92
24	25.80	0.63	24.54	0.68	24.44	0.73	24.34	0.79	24.22	0.79	24.22	0.85	24.10	0.92	23.96

Cast Iron Pipe - AWWA Standard

	Class A			Class B				Class	s C	Class D			
Pipe		100 Ft. 4	43 PSIG	20	0 Ft. 86 PS	IG		300 Ft. 13	0 PSIG	400 Ft. 173 PSIG			
Size	O.D.	WALL	I.D.	O.D.	WALL	I.D.	O.D.	WALL	I.D.	O.D.	WALL	I.D.	
3	3.80	0.39	3.02	3.96	0.42	3.12	3.96	0.45	3.06	3.96	0.48	3.00	
4	4.80	0.42	3.96	5.00	0.45	4.10	5.00	0.48	4.04	5.00	0.52	3.96	
6	6.90	0.44	6.02	7.10	0.48	6.14	7.10	0.51	6.08	7.10	0.55	6.00	
8	9.05	0.46	8.13	9.05	0.51	8.03	9.30	0.56	8.18	9.30	0.60	8.10	
10	11.10	0.50	10.10	11.10	0.57	9.96	11.40	0.62	10.16	11.40	0.68	10.04	
12	13.20	0.54	12.12	13.20	0.62	11.96	13.50	0.68	12.14	13.50	0.75	12.00	
14	15.30	0.57	14.16	15.30	0.66	13.98	15.65	0.74	14.17	15.65	0.82	14.01	
16	17.40	0.60	16.20	17.40	0.70	16.00	17.80	0.80	16.20	17.80	0.89	16.02	
18	19.50	0.64	18.22	19.50	0.75	18.00	19.92	0.87	18.18	19.92	0.96	18.00	
20	21.60	0.67	20.26	21.60	0.80	20.00	22.06	0.92	20.22	22.06	1.03	20.00	
24	25.80	0.76	24.28	25.80	0.89	24.02	26.32	1.04	24.22	26.32	1.16	24.00	
30	31.74	0.88	29.98	32.00	1.03	29.94	32.40	1.20	30.00	32.74	1.37	30.00	
36	37.96	0.99	35.98	38.30	1.15	36.00	38.70	1.36	39.98	39.16	1.58	36.00	
42	44.20	1.10	42.00	44.50	1.28	41.94	45.10	1.54	42.02	45.58	1.78	42.02	
48	50.50	1.26	47.98	50.80	1.42	47.96	51.40	1.71	47.98	51.98	1.96	48.06	
54	56.66	1.35	53.96	57.10	1.55	54.00	57.80	1.90	54.00	58.40	2.23	53.94	
60	62.80	1.39	60.02	63.40	1.67	60.06	64.20	2.00	60.20	64.82	2.38	60.06	
72	75.34	1.62	72.10	76.00	1.95	72.10	76.88	2.39	72.10				
84	87.54	1.72	84.10	88.54	2.22	84.10							

		Clas	ss E	Class F				Clas	s G	Class H			
Pipe		500 Ft. 2	217 PSIG	600 Ft. 260 PSIG				700 Ft. 30	04 PSIG	800 Ft. 347 PSIG			
Size	O.D. WALL I.D.		I.D.	O.D.	WALL	I.D.	O.D.	O.D. WALL I.D.		O.D.	WALL	I.D.	
6	7.22	0.58	6.06	7.22	0.61	6.00	7.38	0.65	6.08	7.38	0.69	6.00	
8	9.42	0.66	8.10	9.42	0.71	8.00	9.60	0.75	8.10	9.60	0.80	8.00	
10	11.60	0.74	10.12	11.60	0.80	10.00	11.84	0.86	10.12	11.84	0.92	10.00	
12	13.78	0.82	12.14	13.78	0.89	12.00	14.08	0.97	12.14	14.08	1.04	12.00	
14	15.98	0.90	14.18	15.98	0.99	14.00	16.32	1.07	14.18	16.32	1.16	14.00	
16	18.16	0.98	16.20	18.16	1.08	16.00	18.54	1.18	16.18	18.54	1.27	16.00	
18	20.34	1.07	18.20	20.34	1.17	18.00	20.78	1.28	18.22	20.78	1.39	18.00	
20	22.54	1.15	20.24	22.54	1.27	20.00	23.02	1.39	20.24	23.02	1.51	20.00	
24	26.90	1.31	24.28	26.90	1.45	24.00	27.76	1.75	24.26	27.76	1.88	24.00	
30	33.10	1.55	30.00	33.46	1.73	30.00]					
36	39.60	1.80	36.00	40.04	2.02	36.00							

Copper Tubing

Pipe	ĸ			L			М			Copper & Brass Pipe			Aluminum		
Size	O.D.	I.D.	WALL	O.D.	I.D.	WALL	0.D.	I.D.	WALL	0.D.	I.D.	WALL	O.D.	I.D.	WALL
2"	2.125	1.959	0.083	2.125	1.985	0.070	2.125	2.009	0.058	2.375	2.062	0.157			
2 1/2	2.625	2.435	0.095	2.625	2.465	0.080	2.625	2.495	0.065	2.875	2.500	0.188	2.500	2.400	0.050
3"	3.125	2.907	0.109	3.125	2.945	0.090	3.125	2.981	0.072	3.500	3.062	0.219	3.000	2.900	0.050
3 1⁄2"	3.625	3.385	0.120	3.625	3.425	0.100	3.625	3.459	0.083	4.000	3.500	0.250			
4"	4.125	3.857	0.134	4.125	3.905	0.110	4.125	3.935	0.095	4.500	3.935	0.095	4.000	4.000	0.250
4 1⁄2"													5.000	4.500	0.250
5"	5.125	4.805	0.160	5.125	4.875	0.125	5.125	4.907	0.109	5.563	5.063	0.250	5.000	4.874	0.063
6"	6.125	5.741	0.192	6.125	5.845	0.140	6.125	5.881	0.122	6.625	6.125	0.250	6.000	5.874	0.063
7"										7.625	7.062	0.282	7.000	6.844	0.078
8"	8.125	7.583	0.271	8.125	7.725	0.200	8.125	7.785	0.170	8.625	8.000	0.313	8.000	7.812	0.094
10"	10.125	9.449	0.338	10.125	9.625	0.250	10.125	9.701	0.212	10.000	9.812	0.094			
12"	12.125	11.315	0.405	12.125	11.565	0.280	12.125	11.617	0.254						

	n	
.,	~	_

Pipe	Pipe		DR 7		DR 7.3		DR 9		DR 11		DR 13.5		DR 15.5	
Size		Wall	ID											
2"	2.375"	0.339"	1.656"	0.325"	1.685"	0.264"	1.816"	0.216"	1.917"	0.176"	2.002"	0.153"	2.050"	
3"	3.500"	0.500"	2.440"	0.479"	2.484"	0.389"	2.676"	0.318"	2.825"	0.259"	2.950"	0.226"	3.021"	
4"	4.500"	0.643"	3.137"	0.616"	3.193"	0.500"	3.440"	0.409"	3.633"	0.333"	3.793"	0.290"	3.885"	
5"	5.563"	0.795"	3.878"	0.762"	3.947"	0.618"	4.253"	0.506"	4.491"	0.412"	4.689"	0.347"	4.640"	
6"	6.625"	0.946"	4.619"	0.908"	4.701"	0.736"	5.064"	0.602"	5.348"	0.491"	5.585"	0.359"	4.802"	
7"	7.125"	1.018"	4.967"	0.976"	5.056"	0.792"	5.447"	0.648"	5.752"	0.528"	6.006"	0.427"	5.719"	
8"	8.625"	1.232"	6.013"	1.182"	6.120"	0.958"	6.593"	0.784"	6.963"	0.639"	7.271"	0.460"	6.150"	
10"	10.750"	1.536"	7.494"	1.473"	7.628"	1.194"	8.218"	0.977"	8.678"	0.796"	9.062"	0.556"	7.445"	
12"	12.750"	1.821"	8.889"	1.747"	9.047"	1.417"	9.747"	1.159"	10.293"	0.944"	10.748"	0.694"	9.280"	
14"	14.000"	2.000"	9.760"	1.918"	9.934"	1.556"	10.702"	1.273"	11.302"	1.037"	11.801"	0.823"	11.006"	
16"	16.00"	2.286"	11.154"	2.192"	11.353"	1.778"	12.231"	1.455"	12.916"	1.185"	13.487"	0.903"	12.085"	
18"	18.00"	2.571"	12.549"	2.466"	12.773"	2.000"	13.760"	1.636"	14.531"	1.333"	15.173"	1.032"	13.812"	
20"	20.00"	2.857"	13.943"	2.740"	14.192"	2.222"	15.289"	1.818"	16.145"	1.481"	16.859"	1.161"	15.538"	
22"	22.00"	3.143"	15.337"	3.014"	15.611"	2.444"	16.818"	2.000"	17.760"	1.630"	18.545"	1.290"	17.265"	
24"	24.00"	3.429"	16.731"	3.288"	17.030"	2.667"	18.347"	2.182"	19.375"	1.778"	20.231"	1.419"	18.991"	
26"	26.00"			3.562"	18.449"	2.889"	19.876"	2.364"	20.989"	1.926"	21.917"	1.548"	20.717"	
28"	28.00"					3.111"	21.404"	2.545"	22.604"	2.074"	23.603"	1.677"	22.444"	
30"	30.00"					3.333"	22.933"	2.727"	24.218"	2.222"	25.289"	1.806"	24.170"	
32"	32.00"					3.556"	24.462"	2.909"	25.833"	2.370"	26.975"	1.935"	25.897"	
34"	34.00"							3.091"	27.447"	2.519"	28.661"	2.065"	27.623"	
36"	36.00"							3.273"	29.062"	2.667"	30.347"	2.194"	29.350"	
42"	42.00"									3.111"	35.404"	2.323"	31.076"	
48"	48.00"									3.556"	40.462"	2.710"	36.255"	
Pipe Size	OD	DR14		DR18		DR-21		DR25						
--------------	-------	-------	--------	-------	--------	-------	--------	-------	--------					
		Wall	ID	Wall	ID	Wall	ID	Wall	ID					
4	4.80	0.343	4.114	0.267	4.266			0.192	4.416					
6	6.90	0.493	5.914	0.383	6.134			0.276	6.348					
8	9.05	0.646	7.758	0.503	8.044			0.362	8.326					
10	11.10	0.793	9.514	0.617	9.866			0.444	10.212					
12	13.20	0.943	11.314	0.733	11.734			0.528	12.144					
14	15.30			0.850	13.600	0.729	13.842	0.612	14.076					
16	17.40			0.967	15.466	0.829	15.742	0.696	16.008					
18	19.50			1.083	17.334	0.929	17.642	0.780	17.94					
20	21.60			1.200	19.200	1.029	19.542	0.864	19.872					
24	25.80			1.433	22.934	1.229	23.342	1.032	23.736					

C900/C905 PVC AWWA Water Distribution Pipe (Blue)

DFM 6.1 INSTRUCTION MANUAL



www.pulsarmeasurement.com

service@pulsarmeasurement.com

Copyright © 2020 Pulsar Measurement Ltd.. Registered Address: 1 Chamberlain Square CS, Birmingham B3 3AX Registered No.: 3345604 England & Wales Rev 1.0