



Certificate of Compliance

Certificate: 1111348 ((LR 88952-7))

Master Contract: 157123

Project: 2392114

Date Issued: April 26, 2011

Issued to: Precision Digital Corporation

89 October Hill Rd, Suite 5
Holliston, MA 01746-1378
USA
Attention: Scott Ewen

The products listed below are eligible to bear the CSA Mark shown



Ezio Migliozi

Issued by: Ezio Migliozi

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe, Entity - For Hazardous Locations

Class I, Div. 1, Groups A, B, C and D; Class II, Div. 1, Groups E, F and G; Class III, Div. 1; Type 4X:

- Model PD686 Loop Powered Indicator, rated 30V dc, 30mA; intrinsically safe when connected per installation Dwg No 1155; $V_{max} = 30V$, $I_{max} = 175mA$, $P_i = 1.3 W$, $C_i = 0$, $L_i = 0$; Temperature Code T4.

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III, Div. 2; Type 4X:

- Model PD686 Loop Powered Indicators, rated 30V dc, 30mA.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-10 - General Requirements – Canadian Electrical Code, Part II

CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 - Process Control Equipment



Certificate: 1111348 ((LR 88952-7))

Master Contract: 157123

Project: 2392114

Date Issued: April 26, 2011

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations