



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1111658

Master Contract: 157123

Project: 2392117

Date Issued: April 26, 2011

Issued to: Precision Digital Corporation

89 October Hill Rd, Suite 5
Holliston, MA 01746-1378
USA
Attention: Scott Ewen

The products listed below are eligible to bear the CSA Mark shown



Ezio Migliozi

Issued by: Ezio Migliozi

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III, Div. 2; Type 4X:

- Model PD675-N, PD675-A, PD676-N and PD676-A Loop Powered Indicators, rated 30V dc, 30mA; Max. Ambient 65 Deg C.

APPLICABLE REQUIREMENTS

CAN/CSA Std C22.2 No 0 M1991 General Requirements Canadian Electrical Code Part II.

CAN/CSA Std C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

CAN/CSA Std C22.2 No.94-M91 - Special Purpose Enclosures

CAN/CSA Std C22.2 No.142-M1987- Process Control Equipment

CAN/CSA Std C22.2 No. 213-M1987- Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations